



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Attention:

Report for Lab No: 40827.
Samples picked up by Martel on May 15, 2019
Project Identification: MD HB 270
School: 07 Malcolm Elementary School.

Monday, October 21, 2019

**Certificate of Analysis
FINAL**

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40827 000001	cafeteria: water fountain -DF	05/09/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	10/18/2019 20:48 BJ
40827 000002	art room : sink-CF	05/09/2019 05:01
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	48.5 ug/l* EPA .200.8 2	10/18/2019 21:00 BJ
40827 000003	art room : bubbler-DF	05/09/2019 05:02
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	12.5 ug/l EPA .200.8 2	10/18/2019 21:03 BJ
40827 000004	kitchen : 2 compartment-KS	05/09/2019 05:03
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	10/18/2019 21:05 BJ
40827 000005	kitchen : ice maker-IM	05/09/2019 05:04
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	10/18/2019 21:08 BJ
40827 000006	kitchen : 2 compartment-KS	05/09/2019 05:05
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	7.31 ug/l EPA .200.8 2	10/18/2019 21:10 BJ



MARTEL NO. 40827 000007 CLIENT SAMPLE IDENTIFICATION gym: water fountain -DF Sample Date/Time 05/09/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.03	ug/l	EPA .200.8	2	10/18/2019 21:12 BJ

MARTEL NO. 40827 000008 CLIENT SAMPLE IDENTIFICATION nurse office: sink-NO Sample Date/Time 05/09/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.32	ug/l	EPA .200.8	2	10/18/2019 21:15 BJ

MARTEL NO. 40827 000009 CLIENT SAMPLE IDENTIFICATION corridor: water fountain L-DF Sample Date/Time 05/09/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.98	ug/l	EPA .200.8	2	10/18/2019 21:17 BJ

MARTEL NO. 40827 000010 CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF Sample Date/Time 05/09/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/18/2019 21:20 BJ

MARTEL NO. 40827 000011 CLIENT SAMPLE IDENTIFICATION corridor: water fountain -DF Sample Date/Time 05/09/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.88	ug/l	EPA .200.8	2	10/18/2019 21:30 BJ

MARTEL NO. 40827 000012 CLIENT SAMPLE IDENTIFICATION Kindergarten classroom 101: sink-CF Sample Date/Time 05/09/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.69	ug/l	EPA .200.8	2	10/18/2019 21:35 BJ

MARTEL NO. 40827 000013 CLIENT SAMPLE IDENTIFICATION Kindergarten classroom 101: bubbler-DF Sample Date/Time 05/09/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.1	ug/l*	EPA .200.8	2	10/18/2019 21:37 BJ

MARTEL NO. 40827 000014 CLIENT SAMPLE IDENTIFICATION Classroom 103: sink-CF Sample Date/Time 05/09/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	204	ug/l*	EPA .200.8	2	10/18/2019 21:40 BJ



MARTEL NO. 40827 000015 Classroom 103: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	82.0	ug/l*	EPA .200.8	2	10/18/2019 21:42 BJ

MARTEL NO. 40827 000016 Pre-K Classroom 130: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.65	ug/l	EPA .200.8	2	10/18/2019 21:44 BJ

MARTEL NO. 40827 000017 Pre-K Classroom 130: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/18/2019 21:47 BJ

MARTEL NO. 40827 000018 Pre-K Classroom 130: sink-CR CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.63	ug/l	EPA .200.8	2	10/18/2019 21:49 BJ

MARTEL NO. 40827 000019 Classroom 105: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.8	ug/l	EPA .200.8	2	10/18/2019 21:52 BJ

MARTEL NO. 40827 000020 Classroom 105: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.3	ug/l	EPA .200.8	2	10/18/2019 21:54 BJ

MARTEL NO. 40827 000021 corridor: water fountain L-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.60	ug/l	EPA .200.8	2	10/18/2019 22:07 BJ

MARTEL NO. 40827 000022 corridor: water fountain R-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/18/2019 22:19 BJ



MARTEL NO. 40827 000023 Classroom 106: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.2	ug/l*	EPA .200.8	2	10/18/2019 22:21 BJ

MARTEL NO. 40827 000024 Classroom 106: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.37	ug/l	EPA .200.8	2	10/18/2019 22:24 BJ

MARTEL NO. 40827 000025 Classroom 107: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.6	ug/l*	EPA .200.8	2	10/18/2019 22:26 BJ

MARTEL NO. 40827 000026 Classroom 107: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.4	ug/l	EPA .200.8	2	10/18/2019 22:29 BJ

MARTEL NO. 40827 000027 Classroom 108-special ed: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	33.5	ug/l*	EPA .200.8	2	10/18/2019 22:31 BJ

MARTEL NO. 40827 000028 Classroom 108-special ed: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	127	ug/l*	EPA .200.8	2	10/18/2019 22:33 BJ

MARTEL NO. 40827 000029 Classroom 108-special ed: sink-CR CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.0	ug/l	EPA .200.8	2	10/18/2019 22:36 BJ

MARTEL NO. 40827 000030 Classroom 109: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	29.0	ug/l*	EPA .200.8	2	10/18/2019 22:38 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40827	000031	Classroom 109: bubbler-DF	05/09/2019 05:31			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.94	ug/l	EPA .200.8	2	10/18/2019 22:49 BJ	
40827	000032	Classroom 110: sink-CF	05/09/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	26.6	ug/l*	EPA .200.8	2	10/18/2019 22:53 BJ	
40827	000033	Classroom 110: bubbler-DF	05/09/2019 05:33			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	15.7	ug/l	EPA .200.8	2	10/18/2019 22:56 BJ	
40827	000034	Music Room: sink-CF	05/09/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	19.6	ug/l	EPA .200.8	2	10/18/2019 22:58 BJ	
40827	000035	Music Room: bubbler-DF	05/09/2019 05:35			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.47	ug/l	EPA .200.8	2	10/18/2019 23:01 BJ	
40827	000036	corridor: water fountain -DF	05/09/2019 05:36			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/18/2019 23:03 BJ	
40827	000037	corridor: water fountain -DF	05/09/2019 05:37			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/18/2019 23:06 BJ	
40827	000038	Classroom 113: sink-CF	05/09/2019 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.93	ug/l	EPA .200.8	2	10/18/2019 23:08 BJ	



MARTEL NO. 40827 000039 CLIENT SAMPLE IDENTIFICATION Classroom 113: bubbler-DF Sample Date/Time 05/09/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	24.6	ug/l*	EPA .200.8	2	10/18/2019 23:11 BJ

MARTEL NO. 40827 000040 CLIENT SAMPLE IDENTIFICATION classroom 114: sink-CF Sample Date/Time 05/09/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	82.7	ug/l*	EPA .200.8	2	10/18/2019 23:13 BJ

MARTEL NO. 40827 000041 CLIENT SAMPLE IDENTIFICATION classroom 114: bubbler-DF Sample Date/Time 05/09/2019 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	24.7	ug/l*	EPA .200.8	2	10/18/2019 23:25 BJ

MARTEL NO. 40827 000042 CLIENT SAMPLE IDENTIFICATION Classroom 115 : sink-CF Sample Date/Time 05/09/2019 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/18/2019 23:38 BJ

MARTEL NO. 40827 000043 CLIENT SAMPLE IDENTIFICATION Classroom 115 : bubbler-DF Sample Date/Time 05/09/2019 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.84	ug/l	EPA .200.8	2	10/18/2019 23:40 BJ

MARTEL NO. 40827 000044 CLIENT SAMPLE IDENTIFICATION Classroom 116: sink-CF Sample Date/Time 05/09/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	58.0	ug/l*	EPA .200.8	2	10/18/2019 23:43 BJ

MARTEL NO. 40827 000045 CLIENT SAMPLE IDENTIFICATION Classroom 116: bubbler-DF Sample Date/Time 05/09/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	17.7	ug/l	EPA .200.8	2	10/18/2019 23:45 BJ

MARTEL NO. 40827 000046 CLIENT SAMPLE IDENTIFICATION Classroom 117: sink-CF Sample Date/Time 05/09/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	17.5	ug/l	EPA .200.8	2	10/18/2019 23:48 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40827 000047	Classroom 117: bubbler-DF	05/09/2019 05:09			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	33.6	ug/l*	EPA .200.8	2	10/18/2019 23:50 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40827 000048	corridor: water fountain -DF	05/09/2019 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.28	ug/l	EPA .200.8	2	10/18/2019 23:53 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40827 000049	corridor: water fountain -DF	05/09/2019 05:11			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/18/2019 23:55 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40827 000050	Classroom 118: sink-CF	05/09/2019 05:12			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.44	ug/l	EPA .200.8	2	10/18/2019 23:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40827 000051	Classroom 118: bubbler-DF	05/09/2019 05:13			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.38	ug/l	EPA .200.8	2	10/19/2019 00:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40827 000052	Classroom 119: sink-CF	05/09/2019 05:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.6	ug/l*	EPA .200.8	2	10/19/2019 00:13 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40827 000053	Classroom 119: bubbler-DF	05/09/2019 05:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.0	ug/l	EPA .200.8	2	10/19/2019 00:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40827 000054	Classroom 120: sink-CF	05/09/2019 05:16			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	78.6	ug/l*	EPA .200.8	2	10/19/2019 00:18 BJ



MARTEL NO. 40827 000055 Classroom 120: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	23.7	ug/l*	EPA .200.8	2	10/19/2019 00:20 BJ

MARTEL NO. 40827 000056 Classroom 121: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	169	ug/l*	EPA .200.8	2	10/19/2019 00:22 BJ

MARTEL NO. 40827 000057 Classroom 121: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	69.1	ug/l*	EPA .200.8	2	10/19/2019 00:25 BJ

MARTEL NO. 40827 000058 Classroom 122: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	32.3	ug/l*	EPA .200.8	2	10/19/2019 00:27 BJ

MARTEL NO. 40827 000059 Classroom 122: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	22.6	ug/l*	EPA .200.8	2	10/19/2019 00:30 BJ

MARTEL NO. 40827 000060 Classroom 123: sink-CF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	134	ug/l*	EPA .200.8	2	10/19/2019 00:33 BJ

MARTEL NO. 40827 000061 Classroom 123: bubbler-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	30.5	ug/l*	EPA .200.8	2	10/19/2019 00:45 BJ

MARTEL NO. 40827 000062 nurse office: ice maker-IM CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/09/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.05	ug/l	EPA .200.8	2	10/19/2019 00:57 BJ



Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

Page 9 OF 9
10/21/2019
stdl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody

40827

Martel Laboratories JDS, Inc. 1025 Cromwell Bridge Road, Baltimore, Maryland 21286 410 825-7790, Fax 410 821-1054, email: martel@martellabs.com

Charles County PS Drinking Water Lead Testing 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

ALL OUTLETS WERE FLUSHED NIGHT BEFORE SAMPLING AS BELOW:

BETWEEN 5-8-19 6:30 PM and 5-8-19 8:00 PM

Sampling Date: 5-9-19 5:00 AM Relinquished By: Alan Shirley

Notes
All Fixtures flushed for 3 minutes

Received at Martel by [Signature] Date/Time: 5/15/19 12:15

Jawon Cook S115119 1515
07 Malcolm Elementary School PSC #08.024 14760 Poplar Hill Road
Waldorf, MD 20601

(No water in Trailers.)

Martel Lab No: **40827**

School Dude Work Order # 17927

Sample Floor Plan Id #	Outlet Code	Bldg Floor	Description Location	Time	Sampler Employee Code	Notes
1	DF	Main Bldg	cafeteria-water fountain	5:00 AM	36552	
2	CF	1st floor	art room -sink	5:01		
3	DF		art room -bubbler	5:02		
4	KS		kitchen -2 compartment	5:03		
5	IM		kitchen -ice maker	5:04		
6	KS		kitchen -2 compartment	5:05		
7	DF		gym-water fountain	5:06		
8	NO		nurse office-sink	5:07		
9	DF		corridor-water fountain L	5:08		
10	DF		corridor-water fountain R	5:09		
11	DF		corridor-water fountain	5:11		
12	CF		Kindergarten classroom 101-sink	5:12		
13	DF		Kindergarten classroom 101-bubbler	5:13		
14	CF		Classroom 103-sink	5:14		
15	DF		Classroom 103-bubbler	5:15		
16	CF		Pre-K Classroom 130-sink	5:16		
17	DF		Pre-K Classroom 130-bubbler	5:17		
18	CR		Pre-K Classroom 130-sink	5:18		
19	CF		Classroom 105-sink	5:19		
20	DF		Classroom 105-bubbler	5:20		
21	DF		corridor-water fountain L	5:21		
22	DF		corridor-water fountain R	5:22		
23	CF		Classroom 106-sink	5:23		
24	DF		Classroom 106-bubbler	5:24		
25	CF		Classroom 107-sink	5:25		

MARTEL Chain of Custody

40827

26	DF		Classroom 107-bubbler	5:26	36552	
27	CF		Classroom 108-special ed-sink	5:27		
28	DF		Classroom 108-special ed-bubbler	5:28		
29	CR		Classroom 108-special ed-sink	5:29		
30	CF		Classroom 109-sink	5:30		
31	DF		Classroom 109-bubbler	5:31		
32	CF		Classroom 110-sink	5:32		
33	DF		Classroom 110-bubbler	5:33		
34	CF		Music Room-sink	5:34		
35	DF		Music Room-bubbler	5:35		
36	DF		corridor-water fountain	5:36		
37	DF		corridor-water fountain	5:37		▼
38	CF		Classroom 113-sink	5:00	33226	
39	DF		Classroom 113-bubbler	5:01		
40	CF		classroom 114-sink	5:02		
41	DF		classroom 114-bubbler	5:03		
42	CF		Classroom 115 -sink	5:04		
43	DF		Classroom 115 -bubbler	5:05		
44	CF		Classroom 116-sink	5:06		
45	DF		Classroom 116-bubbler	5:07		
46	CF		Classroom 117-sink	5:08		
47	DF		Classroom 117-bubbler	5:09		
48	DF		corridor-water fountain	5:10		
49	DF		corridor-water fountain	5:11		
50	CF		Classroom 118-sink	5:12		
51	DF		Classroom 118-bubbler	5:13		
52	CF		Classroom 119-sink	5:14		
53	DF		Classroom 119-bubbler	5:15		
54	CF		Classroom 120-sink	5:16		
55	DF		Classroom 120-bubbler	5:17		
56	CF		Classroom 121-sink	5:18		
57	DF		Classroom 121-bubbler	5:19		
58	CF		Classroom 122-sink	5:20		
59	DF		Classroom 122-bubbler	5:21		
60	CF		Classroom 123-sink	5:22		▼

MARTEL Chain of Custody

40827

61	DF		Classroom 123-bubbler	5:23	33226	
62	IM		nurse office	5:24		
63	OT		Pump House Main Water test sample	5:25		
64						
65						
66						
67						
68						
69						
70						