



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Monday, August 19, 2019

Certificate of Analysis
FINAL

Attention:

Report for Lab No: 40832 picked up on May 15, 2019.
Project Identification: MD HB 270
School: 71 Annex I

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40832 000001	kitchen 1st floor: sink on left-KS	05/11/2019 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 08/16/2019 16:07 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40832 000002	kitchen 1st floor: sink on right-KS	05/11/2019 05:02
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 08/16/2019 16:13 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40832 000004	kitchen : coffee maker-KS	05/11/2019 05:05
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 08/16/2019 16:18 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40832 000005	kitchen : ice maker-IM	05/11/2019 05:05
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 08/16/2019 16:21 BJ



Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

Page 2 OF 2

08/19/2019

stddl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.



Project Manager