



**Charles County Public Schools**

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

Monday, June 17, 2019

**Certificate of Analysis  
FINAL**

**Attention:**

Report for Lab No: 40802.  
Samples picked up by Martel on March 20, 2019.  
Project Identification: MD HB 270  
School: 22 Berry Elementary School.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40802 000001	BES-1-FS: kitchen 3 comp sink-sink on left	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.71	ug/l	EPA .200.8	2	06/14/2019 15:06 BJ
40802 000002	BES-2-FS: kitchen 3 comp sink-sink on right	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.56	ug/l	EPA .200.8	2	06/14/2019 15:18 BJ
40802 000003	BES-3-FS: kitchen sink-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.96	ug/l	EPA .200.8	2	06/14/2019 15:21 BJ
40802 000004	BES-4-FS: kitchen 2 comp sink-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.79	ug/l	EPA .200.8	2	06/14/2019 15:23 BJ
40802 000005	BES-5-IM: kitchen -ice maker	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 15:26 BJ
40802 000006	BES-6-CF: music room-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	18.3	ug/l	EPA .200.8	2	06/14/2019 15:28 BJ



MARTEL NO. 40802      000007      CLIENT SAMPLE IDENTIFICATION BES-7-DF: music room-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 15:31 BJ

MARTEL NO. 40802      000008      CLIENT SAMPLE IDENTIFICATION BES-8-DF: corridor-water fountain      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 15:33 BJ

MARTEL NO. 40802      000009      CLIENT SAMPLE IDENTIFICATION BES-9-DF: corridor-water fountain      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 15:36 BJ

MARTEL NO. 40802      000010      CLIENT SAMPLE IDENTIFICATION BES-10-CF: Classroom 32-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 15:38 BJ

MARTEL NO. 40802      000011      CLIENT SAMPLE IDENTIFICATION BES-11-DF: Classroom 32-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 15:48 BJ

MARTEL NO. 40802      000012      CLIENT SAMPLE IDENTIFICATION BES-12-CF: Classroom 24-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.21	ug/l	EPA .200.8	2	06/14/2019 15:54 BJ

MARTEL NO. 40802      000013      CLIENT SAMPLE IDENTIFICATION BES-13-DF: Classroom 24-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 15:56 BJ

MARTEL NO. 40802      000014      CLIENT SAMPLE IDENTIFICATION BES-14-CF: Classroom 23-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.89	ug/l	EPA .200.8	2	06/14/2019 15:58 BJ



MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-15-DF: Classroom 23-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 16:01 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-16-CF: Classroom 22-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.72	ug/l	EPA .200.8	2	06/14/2019 16:03 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-17-DF: Classroom 22-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 16:06 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-18-CF: Classroom 21-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.38	ug/l	EPA .200.8	2	06/14/2019 16:08 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-19-DF: Classroom 21-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 16:11 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-20-CF: Classroom 20-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.04	ug/l	EPA .200.8	2	06/14/2019 16:13 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-21-DF: Classroom 20-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 16:26 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-22-CF: Classroom 19-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.90	ug/l	EPA .200.8	2	06/14/2019 16:38 BJ



MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-23-DF: Classroom 19-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 16:41 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-24-CF: Classroom 18-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.93	ug/l	EPA .200.8	2	06/14/2019 16:43 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-25-DF: Classroom 18-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 16:46 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-26-CF: Intensity 4-5-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.28	ug/l	EPA .200.8	2	06/14/2019 16:48 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-27-DF: Intensity 4-5-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 16:51 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-28-CF: Intensity 4-5-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.44	ug/l	EPA .200.8	2	06/14/2019 16:53 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-29-DF: Intensity 4-5-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 16:56 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-30-CF: Classroom 17-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.88	ug/l	EPA .200.8	2	06/14/2019 16:58 BJ



MARTEL NO. 40802      000031      CLIENT SAMPLE IDENTIFICATION BES-31-DF: Classroom 17-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 17:08 BJ

MARTEL NO. 40802      000032      CLIENT SAMPLE IDENTIFICATION BES-32-CF: Classroom 16-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.75	ug/l	EPA .200.8	2	06/14/2019 17:13 BJ

MARTEL NO. 40802      000033      CLIENT SAMPLE IDENTIFICATION BES-33-DF: Classroom 16-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 17:15 BJ

MARTEL NO. 40802      000034      CLIENT SAMPLE IDENTIFICATION BES-34-CF: Classroom 15-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.18	ug/l	EPA .200.8	2	06/14/2019 17:18 BJ

MARTEL NO. 40802      000035      CLIENT SAMPLE IDENTIFICATION BES-35-DF: Classroom 15-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 17:20 BJ

MARTEL NO. 40802      000036      CLIENT SAMPLE IDENTIFICATION BES-36-CF: Classroom 14-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.27	ug/l	EPA .200.8	2	06/14/2019 17:23 BJ

MARTEL NO. 40802      000037      CLIENT SAMPLE IDENTIFICATION BES-37-DF: Classroom 14-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 17:25 BJ

MARTEL NO. 40802      000038      CLIENT SAMPLE IDENTIFICATION BES-38-CF: Classroom 13-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.78	ug/l	EPA .200.8	2	06/14/2019 17:28 BJ



MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-39-DF: Classroom 13-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 17:30 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-40-DF: corridor-water fountain      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 17:33 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-41-DF: corridor-water fountain      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 17:45 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-42-DF: corridor-water fountain      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 17:58 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-43-DF: corridor-water fountain      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 18:00 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-44-CF: Classroom 12-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.11	ug/l	EPA .200.8	2	06/14/2019 18:03 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-45-DF: Classroom 12-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.79	ug/l	EPA .200.8	2	06/14/2019 18:05 BJ

MARTEL NO. 40802      CLIENT SAMPLE IDENTIFICATION BES-46-CF: Classroom 10-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.62	ug/l	EPA .200.8	2	06/14/2019 18:08 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000047	BES-47-DF: Classroom 10-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 18:10 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000048	BES-48-CF: Classroom 11-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.40	ug/l	EPA .200.8	2	06/14/2019 18:13 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000049	BES-49-DF: Classroom 11-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 18:15 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000050	BES-50-CF: Classroom 9-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.03	ug/l	EPA .200.8	2	06/14/2019 18:18 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000051	BES-51-DF: Classroom 9-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 18:28 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000052	BES-52-CF: Classroom 8-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	8.39	ug/l	EPA .200.8	2	06/14/2019 18:33 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000053	BES-53-DF: Classroom 8-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 18:36 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000054	BES-54-CF: Classroom 7-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.54	ug/l	EPA .200.8	2	06/14/2019 18:38 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000055	BES-55-DF: Classroom 7-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 18:41 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000056	BES-56-CF: Classroom 5-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	6.38	ug/l	EPA .200.8	2	06/14/2019 18:43 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000057	BES-57-DF: Classroom 5-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 18:46 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000058	BES-58-CF: Classroom 6-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.10	ug/l	EPA .200.8	2	06/14/2019 18:48 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000059	BES-59-DF: Classroom 6-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 18:51 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000060	BES-60-CF: Classroom 3-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.27	ug/l	EPA .200.8	2	06/14/2019 18:53 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000061	BES-61-DF: Classroom 3-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 19:06 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000062	BES-62-CF: Classroom 4-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.76	ug/l	EPA .200.8	2	06/14/2019 19:18 BJ	





## Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40802 000063	BES-63-DF: Classroom 4-bubbler	03/20/2019 17:19
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/14/2019 19:21 BJ
40802 000064	BES-64-CF: Classroom 2-sink	03/20/2019 17:19
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.47 ug/l EPA .200.8 2	06/14/2019 19:23 BJ
40802 000065	BES-65-DF: Classroom 2-bubbler	03/20/2019 17:19
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/14/2019 19:26 BJ
40802 000066	BES-66-CF: Classroom 1-sink	03/20/2019 17:19
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.79 ug/l EPA .200.8 2	06/14/2019 19:28 BJ
40802 000067	BES-67-DF: Classroom 1-bubbler	03/20/2019 17:19
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/14/2019 19:31 BJ
40802 000068	BES-68-CF: Preschool-sink	03/20/2019 17:19
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/14/2019 19:33 BJ
40802 000069	BES-69-DF: Preschool-bubbler	03/20/2019 17:19
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/14/2019 19:36 BJ
40802 000070	BES-70-DF: corridor-water fountain	03/20/2019 17:19
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/14/2019 19:38 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000071	BES-71-DF: corridor-water fountain	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 19:49 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000072	BES-72-KS: New addition activity room-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 19:54 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000073	BES-73-CF: Kindergarten 5-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 19:56 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000074	BES-74-DF: Kindergarten 5-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 19:59 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000075	BES-75-CF: PreK-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 20:01 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000076	BES-76-DF: PreK-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 20:04 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000077	BES-77-CF: Kindergarten 3-sink	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 20:06 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40802	000078	BES-78-DF: Kindergarten 3-bubbler	03/20/2019 17:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 20:09 BJ	



MARTEL NO. 40802      000079      CLIENT SAMPLE IDENTIFICATION BES-79-CF: Kindergarten 2-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 20:11 BJ

MARTEL NO. 40802      000080      CLIENT SAMPLE IDENTIFICATION BES-80-DF: Kindergarten 2-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/14/2019 20:14 BJ

MARTEL NO. 40802      000081      CLIENT SAMPLE IDENTIFICATION BES-81-CF: Kindergarten 1-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/11/2019 09:55 BJ

MARTEL NO. 40802      000082      CLIENT SAMPLE IDENTIFICATION BES-82-DF: Kindergarten 1-bubbler      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/11/2019 10:07 BJ

MARTEL NO. 40802      000083      CLIENT SAMPLE IDENTIFICATION BES-83-CR: Teachers lounge-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/11/2019 10:09 BJ

MARTEL NO. 40802      000084      CLIENT SAMPLE IDENTIFICATION BES-84-CR: conference room-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.5	ug/l	EPA .200.8	2	06/11/2019 10:12 BJ

MARTEL NO. 40802      000085      CLIENT SAMPLE IDENTIFICATION BES-85-NO: nurse office-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/11/2019 10:14 BJ

MARTEL NO. 40802      000086      CLIENT SAMPLE IDENTIFICATION PBES-86-CF: Classroom 17-sink      Sample Date/Time 03/20/2019 17:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/11/2019 10:16 BJ



---

MARTEL NO. 40802	000087	CLIENT SAMPLE IDENTIFICATION PBES-87-DF: Classroom 17-bubbler	Sample Date/Time 03/20/2019 17:19		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/11/2019 10:19 BJ

---

MARTEL NO. 40802	000088	CLIENT SAMPLE IDENTIFICATION PBES-88-CF: Teachers lounge-hot water dispe	Sample Date/Time 03/20/2019 17:19		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/11/2019 10:21 BJ

---

Page 12 OF 12

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

**Notes and references:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager