



**Charles County Public Schools**

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

**Attention:**

Report for Lab No: 48201.  
Retest samples picked up by Martel on 12/18/2019.  
Project Identification: MD HB 270  
School: 01 Gustavus Brown ES.

Monday, February 3, 2020

***Certificate of Analysis***  
**FINAL**

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48201 000001	DBES-DF-1: Hallway at Locker Rooms-Water Fountain	12/04/2019 06:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.25	ug/l	EPA .200.8	2	01/24/2020 11:22 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48201 000010	DBES-OT-10: Kitchen-Kettle	12/04/2019 06:24			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	20.3	ug/l	EPA .200.8	2	01/24/2020 11:35 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48201 000045	DBES-CF-45: CR317 -sink on right	12/04/2019 06:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.6	ug/l	EPA .200.8	2	01/24/2020 11:38 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48201 000046	DBES-DF-46: CR317 -bubbler on right	12/04/2019 06:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.6	ug/l	EPA .200.8	2	01/24/2020 11:41 BJ



---

**Martel Laboratories JDS Inc.**

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

Page 2 OF 2

02/03/2020

stdl.frx

---

**Notes and references:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager