

MARTEL



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Tuesday, July 9, 2019

Certificate of Analysis FINAL

Attention:

Report for Lab No: 40804.
Samples picked up by Martel on March 27, 2019
Project Identification: MD HB 270
School: 23 William A. digges Elementary School.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40804 000001	WDES-1-KS: kitchen 3 comp sink-sink on left	03/26/2019 17:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/25/2019 15:45 BJ
40804 000002	WDES-2-KS: kitchen 3 comp sink-sink on right	03/26/2019 17:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	6.68 ug/l EPA .200.8 2	06/25/2019 15:56 BJ
40804 000003	WDES-3-IM: Kitchen-icemaker	03/26/2019 17:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/25/2019 15:59 BJ
40804 000004	WDES-4-KS: Kitchen-sink	03/26/2019 17:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	06/25/2019 16:01 BJ
40804 000005	WDES-5-KS: kitchen sink 2 comp-sink	03/26/2019 17:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	4.33 ug/l EPA .200.8 2	06/25/2019 16:04 BJ
40804 000006	WDES-6-KS: kitchen-sink	03/26/2019 17:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.67 ug/l EPA .200.8 2	06/25/2019 16:06 BJ



MARTEL NO. 40804 000007 CLIENT SAMPLE IDENTIFICATION WDES-7-DF: corridor wing-water fountain Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:08 BJ

MARTEL NO. 40804 000008 CLIENT SAMPLE IDENTIFICATION WDES-8-DF: corridor wing-water fountain Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:11 BJ

MARTEL NO. 40804 000009 CLIENT SAMPLE IDENTIFICATION WDES-9-CF: Classroom D 125-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:13 BJ

MARTEL NO. 40804 000010 CLIENT SAMPLE IDENTIFICATION WDES-10-DF: Classroom D 125-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:16 BJ

MARTEL NO. 40804 000011 CLIENT SAMPLE IDENTIFICATION WDES-11-CF: Classroom D 127-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:26 BJ

MARTEL NO. 40804 000012 CLIENT SAMPLE IDENTIFICATION WDES-12-DF: Classroom D 127-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:31 BJ

MARTEL NO. 40804 000013 CLIENT SAMPLE IDENTIFICATION WDES-13-CF: Classroom D 129-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:33 BJ

MARTEL NO. 40804 000014 CLIENT SAMPLE IDENTIFICATION WDES-14-DF: Classroom D 129-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:35 BJ



MARTEL NO. 40804 000015 CLIENT SAMPLE IDENTIFICATION WDES-15-CF: Classroom D 131-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:38 BJ

MARTEL NO. 40804 000016 CLIENT SAMPLE IDENTIFICATION WDES-16-DF: Classroom D 131-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:40 BJ

MARTEL NO. 40804 000017 CLIENT SAMPLE IDENTIFICATION WDES-17-CF: Classroom D 134-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:43 BJ

MARTEL NO. 40804 000018 CLIENT SAMPLE IDENTIFICATION WDES-18-DF: Classroom D 134-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:45 BJ

MARTEL NO. 40804 000019 CLIENT SAMPLE IDENTIFICATION WDES-19-CF: Classroom D 137-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:47 BJ

MARTEL NO. 40804 000020 CLIENT SAMPLE IDENTIFICATION WDES-20-DF: Classroom D 137-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 16:50 BJ

MARTEL NO. 40804 000021 CLIENT SAMPLE IDENTIFICATION WDES-21-CF: Classroom D 104-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:02 BJ

MARTEL NO. 40804 000022 CLIENT SAMPLE IDENTIFICATION WDES-22-DF: Classroom D 104-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:14 BJ



Certificate of Analysis

MARTEL NO. 40804 000023 CLIENT SAMPLE IDENTIFICATION WDES-23-CF: Classroom D 107-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:17 BJ

MARTEL NO. 40804 000024 CLIENT SAMPLE IDENTIFICATION WDES-24-DF: Classroom D 107-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:19 BJ

MARTEL NO. 40804 000025 CLIENT SAMPLE IDENTIFICATION WDES-25-CF: Classroom D 110-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:21 BJ

MARTEL NO. 40804 000026 CLIENT SAMPLE IDENTIFICATION WDES-26-DF: Classroom D 110-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:24 BJ

MARTEL NO. 40804 000027 CLIENT SAMPLE IDENTIFICATION WDES-27-CF: Classroom D 113-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:26 BJ

MARTEL NO. 40804 000028 CLIENT SAMPLE IDENTIFICATION WDES-28-DF: Classroom D 113-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:29 BJ

MARTEL NO. 40804 000029 CLIENT SAMPLE IDENTIFICATION WDES-29-CF: Classroom D 115-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:31 BJ

MARTEL NO. 40804 000030 CLIENT SAMPLE IDENTIFICATION WDES-30-DF: Classroom D 115-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:33 BJ



MARTEL NO. 40804 000031 CLIENT SAMPLE IDENTIFICATION WDES-31-CF: Classroom D 117-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:43 BJ

MARTEL NO. 40804 000032 CLIENT SAMPLE IDENTIFICATION WDES-32-DF: Classroom D 117-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:48 BJ

MARTEL NO. 40804 000033 CLIENT SAMPLE IDENTIFICATION WDES-33-CF: Classroom E 120-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:50 BJ

MARTEL NO. 40804 000034 CLIENT SAMPLE IDENTIFICATION WDES-34-DF: Classroom E 120-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:53 BJ

MARTEL NO. 40804 000035 CLIENT SAMPLE IDENTIFICATION WDES-35-CF: Classroom E 122-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:55 BJ

MARTEL NO. 40804 000036 CLIENT SAMPLE IDENTIFICATION WDES-36-DF: Classroom E 122-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 17:58 BJ

MARTEL NO. 40804 000037 CLIENT SAMPLE IDENTIFICATION WDES-37-CF: Classroom E 124-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:00 BJ

MARTEL NO. 40804 000038 CLIENT SAMPLE IDENTIFICATION WDES-38-DF: Classroom E 124-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:02 BJ



MARTEL NO. 40804 000039 CLIENT SAMPLE IDENTIFICATION WDES-39-CF: Classroom E 126-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:05 BJ

MARTEL NO. 40804 000040 CLIENT SAMPLE IDENTIFICATION WDES-40-DF: Classroom E 126-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:07 BJ

MARTEL NO. 40804 000041 CLIENT SAMPLE IDENTIFICATION WDES-41-CF: Classroom E 128-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:20 BJ

MARTEL NO. 40804 000042 CLIENT SAMPLE IDENTIFICATION WDES-42-DF: Classroom E 128-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:32 BJ

MARTEL NO. 40804 000043 CLIENT SAMPLE IDENTIFICATION WDES-43-CF: Classroom E 130-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:34 BJ

MARTEL NO. 40804 000044 CLIENT SAMPLE IDENTIFICATION WDES-44-DF: Classroom E 130-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:37 BJ

MARTEL NO. 40804 000045 CLIENT SAMPLE IDENTIFICATION WDES-45-CF: Classroom E 103-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:39 BJ

MARTEL NO. 40804 000046 CLIENT SAMPLE IDENTIFICATION WDES-46-DF: Classroom E 103-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:41 BJ



MARTEL NO. 40804 000047 CLIENT SAMPLE IDENTIFICATION WDES-47-CF: Classroom E 106-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:44 BJ

MARTEL NO. 40804 000048 CLIENT SAMPLE IDENTIFICATION WDES-48-DF: Classroom E 106-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:46 BJ

MARTEL NO. 40804 000049 CLIENT SAMPLE IDENTIFICATION WDES-49-CF: Classroom E 108-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:49 BJ

MARTEL NO. 40804 000050 CLIENT SAMPLE IDENTIFICATION WDES-50-DF: Classroom E 108-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 18:51 BJ

MARTEL NO. 40804 000051 CLIENT SAMPLE IDENTIFICATION WDES-51-CF: Classroom E 110-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:01 BJ

MARTEL NO. 40804 000052 CLIENT SAMPLE IDENTIFICATION WDES-52-DF: Classroom E 110-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:06 BJ

MARTEL NO. 40804 000053 CLIENT SAMPLE IDENTIFICATION WDES-53-DF: corridor -water fountain on left Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:09 BJ

MARTEL NO. 40804 000054 CLIENT SAMPLE IDENTIFICATION WDES-54-DF: corridor-water fountain on right Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:11 BJ



MARTEL NO. 40804 000055 CLIENT SAMPLE IDENTIFICATION WDES-55-CF: Classroom E 116-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:13 BJ

MARTEL NO. 40804 000056 CLIENT SAMPLE IDENTIFICATION WDES-56-DF: Classroom E 116-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:16 BJ

MARTEL NO. 40804 000057 CLIENT SAMPLE IDENTIFICATION WDES-57-CF: Classroom F 120-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:18 BJ

MARTEL NO. 40804 000058 CLIENT SAMPLE IDENTIFICATION WDES-58-DF: Classroom F 120-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:21 BJ

MARTEL NO. 40804 000059 CLIENT SAMPLE IDENTIFICATION WDES-59-CF: Classroom F 122-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:23 BJ

MARTEL NO. 40804 000060 CLIENT SAMPLE IDENTIFICATION WDES-60-DF: Classroom F 122-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 19:26 BJ

MARTEL NO. 40804 000061 CLIENT SAMPLE IDENTIFICATION WDES-61-CF: Classroom F 124-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:13 BJ

MARTEL NO. 40804 000062 CLIENT SAMPLE IDENTIFICATION WDES-62-DF: Classroom F 124-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:25 BJ



MARTEL NO. 40804 CLIENT SAMPLE IDENTIFICATION WDES-63-CF: Classroom F 126-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:27 BJ

MARTEL NO. 40804 CLIENT SAMPLE IDENTIFICATION WDES-64-DF: Classroom F 126-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:29 BJ

MARTEL NO. 40804 CLIENT SAMPLE IDENTIFICATION WDES-65-CF: Classroom F 128-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.06	ug/l	EPA .200.8	2	07/03/2019 17:32 BJ

MARTEL NO. 40804 CLIENT SAMPLE IDENTIFICATION WDES-66-DF: Classroom F 128-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:34 BJ

MARTEL NO. 40804 CLIENT SAMPLE IDENTIFICATION WDES-67-CF: Classroom F 130-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:37 BJ

MARTEL NO. 40804 CLIENT SAMPLE IDENTIFICATION WDES-68-DF: Classroom F 130-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:39 BJ

MARTEL NO. 40804 CLIENT SAMPLE IDENTIFICATION WDES-69-CF: Classroom F 104-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:41 BJ

MARTEL NO. 40804 CLIENT SAMPLE IDENTIFICATION WDES-70-DF: Classroom F 104-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:44 BJ



Certificate of Analysis

MARTEL NO. 40804 000071 CLIENT SAMPLE IDENTIFICATION WDES-71-CF: Classroom F 106-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:54 BJ

MARTEL NO. 40804 000072 CLIENT SAMPLE IDENTIFICATION WDES-72-DF: Classroom F 106-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 17:59 BJ

MARTEL NO. 40804 000073 CLIENT SAMPLE IDENTIFICATION WDES-73-CF: Classroom F 108-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:01 BJ

MARTEL NO. 40804 000074 CLIENT SAMPLE IDENTIFICATION WDES-74-DF: Classroom F 108-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:04 BJ

MARTEL NO. 40804 000075 CLIENT SAMPLE IDENTIFICATION WDES-75-CF: Classroom F 110-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:06 BJ

MARTEL NO. 40804 000076 CLIENT SAMPLE IDENTIFICATION WDES-76-DF: Classroom F 110-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:09 BJ

MARTEL NO. 40804 000077 CLIENT SAMPLE IDENTIFICATION WDES-77-DF: corridor-water fountain on left Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:11 BJ

MARTEL NO. 40804 000078 CLIENT SAMPLE IDENTIFICATION WDES-78-DF: corridor-water fountain on right Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:13 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40804	000079	WDES-79-CF: Classroom F 116-sink	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:16 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40804	000080	WDES-80-DF: Classroom F 116-bubbler	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:18 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40804	000081	WDES-81-NO: Health Room A119-sink	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:30 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40804	000082	WDES-82-CF: Health Room A120-sink	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:43 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40804	000083	WDES-83-DF: Health Room A120-bubbler	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:45 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40804	000084	WDES-84-TL: Staff Lounge A136-sink	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:47 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40804	000085	WDES-85-CF: Classroom B107-sink	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:50 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40804	000086	WDES-86-DF: Classroom B107-bubbler	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:52 BJ	



MARTEL NO. 40804 000087 CLIENT SAMPLE IDENTIFICATION WDES-87-DF: corridor-water fountain on left Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:55 BJ

MARTEL NO. 40804 000088 CLIENT SAMPLE IDENTIFICATION WDES-88-DF: corridor-water fountain on right Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:57 BJ

MARTEL NO. 40804 000089 CLIENT SAMPLE IDENTIFICATION WDES-89-DF: corridor-water fountain on left Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 18:59 BJ

MARTEL NO. 40804 000090 CLIENT SAMPLE IDENTIFICATION WDES-90-DF: corridor-water fountain on right Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 19:02 BJ

MARTEL NO. 40804 000091 CLIENT SAMPLE IDENTIFICATION WDES-91-CR: classroom B116 - coffee pot manu Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 19:11 BJ

MARTEL NO. 40804 000092 CLIENT SAMPLE IDENTIFICATION WDES-92-CF: Classroom B111-sink Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 19:16 BJ

MARTEL NO. 40804 000093 CLIENT SAMPLE IDENTIFICATION WDES-93-DF: Classroom B111-bubbler Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 19:19 BJ

MARTEL NO. 40804 000094 CLIENT SAMPLE IDENTIFICATION WDES-94-DF: Main Office-water fountain on le Sample Date/Time 03/26/2019 17:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 19:21 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40804 000095	WDES-95-DF: Main Office-water fountain on ri	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 19:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40804 000096	WDES- 96-CF: A134-sink	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 19:26 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40804 000097	WDES-97-DF: A134-bubbler	03/26/2019 17:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/03/2019 19:28 BJ

Page 13 OF 13


1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager