


MARTEL



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Monday, October 14, 2019

Certificate of Analysis FINAL

Attention:

Report for Lab No: 40829.
Samples picked up by Martel on May 8, 2019.
Project Identification: MD HB 270
School: 03 Gale-Bailey Elementary School.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40829 000001	PBES-1-KS: loading dock corridor-water fountain	05/07/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.70 ug/l EPA .200.8 2	10/11/2019 16:24 BJ
40829 000002	PBES-2-KS: kitchen-sink on left	05/07/2019 05:02
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	10/11/2019 16:36 BJ
40829 000003	: kitchen-sink in middle	05/07/2019 05:04
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.20 ug/l EPA .200.8 2	10/11/2019 16:38 BJ
40829 000004	: kitchen-sink on right	05/07/2019 05:06
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	10/11/2019 16:40 BJ
40829 000005	: kitchen-kettle	05/07/2019 05:08
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	10.3 ug/l EPA .200.8 2	10/11/2019 16:43 BJ
40829 000006	: kitchen-ice maker	05/07/2019 05:10
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	10/11/2019 16:45 BJ



MARTEL NO. 40829	000007	CLIENT SAMPLE IDENTIFICATION : cafeteria-water fountain	Sample Date/Time 05/07/2019 05:12
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial	10/11/2019 16:48 BJ

MARTEL NO. 40829	000008	CLIENT SAMPLE IDENTIFICATION : main office-water fountain	Sample Date/Time 05/07/2019 05:14
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial	10/11/2019 16:50 BJ

MARTEL NO. 40829	000009	CLIENT SAMPLE IDENTIFICATION : corridor-water fountain	Sample Date/Time 05/07/2019 05:16
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial	10/11/2019 16:52 BJ

MARTEL NO. 40829	000010	CLIENT SAMPLE IDENTIFICATION : teachers lounge-sink	Sample Date/Time 05/07/2019 05:18
Compound	Test Value	Test Unit	Method
Lead	3.50	ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial	10/11/2019 16:55 BJ

MARTEL NO. 40829	000011	CLIENT SAMPLE IDENTIFICATION : teachers lounge-bubbler	Sample Date/Time 05/07/2019 05:20
Compound	Test Value	Test Unit	Method
Lead	11.3	ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial	10/11/2019 17:05 BJ

MARTEL NO. 40829	000012	CLIENT SAMPLE IDENTIFICATION : corridor-water fountain	Sample Date/Time 05/07/2019 05:22
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial	10/11/2019 17:10 BJ

MARTEL NO. 40829	000013	CLIENT SAMPLE IDENTIFICATION : classroom 26-sink	Sample Date/Time 05/07/2019 05:24
Compound	Test Value	Test Unit	Method
Lead	2.55	ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial	10/11/2019 17:12 BJ

MARTEL NO. 40829	000014	CLIENT SAMPLE IDENTIFICATION : classroom 26-bubbler	Sample Date/Time 05/07/2019 05:26
Compound	Test Value	Test Unit	Method
Lead	2.34	ug/l	EPA .200.8
Detection Limit	2	Analysis Date/Time/Initial	10/11/2019 17:15 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000017	: classroom 21-sink	05/07/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 17:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000018	: classroom 21-bubbler	05/07/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 17:20 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000019	: classroom 104-sink	05/07/2019 05:36			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	21.8	ug/l*	EPA .200.8	2	10/11/2019 17:22 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000020	: classroom 104-bubbler	05/07/2019 05:38			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.79	ug/l	EPA .200.8	2	10/11/2019 17:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000021	: classroom 105-sink	05/07/2019 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 17:37 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000022	: classroom 105-bubbler	05/07/2019 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 17:49 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000023	: classroom 107-sink	05/07/2019 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.17	ug/l	EPA .200.8	2	10/11/2019 17:51 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000024	: classroom 107-bubbler	05/07/2019 05:46			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 17:53 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000025	: activity area-sink	05/07/2019 05:48			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 17:56 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000026	: activity area-sink	05/07/2019 05:50			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 17:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000027	: activity area-bubbler	05/07/2019 05:52			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 18:01 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000028	: classroom 108-sink	05/07/2019 05:54			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 18:03 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000029	: classroom 108-sink	05/07/2019 05:55			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 18:05 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000030	: classroom 108-bubbler	05/07/2019 05:56			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 18:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000031	: classroom 110B-sink	05/07/2019 05:57			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.02	ug/l	EPA .200.8	2	10/11/2019 18:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40829 000032	: classroom 110B-bubbler	05/07/2019 05:58			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 18:22 BJ



MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000033 : corridor-water fountain 05/07/2019 05:59

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 18:25 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000034 : classroom 109-sink 05/07/2019 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.31	ug/l	EPA .200.8	2	10/11/2019 18:27 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000035 : classroom 109-bubbler 05/07/2019 06:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.49	ug/l	EPA .200.8	2	10/11/2019 18:30 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000036 : classroom 110-sink 05/07/2019 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.43	ug/l	EPA .200.8	2	10/11/2019 18:32 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000037 : classroom 110-bubbler 05/07/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.08	ug/l	EPA .200.8	2	10/11/2019 18:34 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000038 : classroom 111-sink 05/07/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.08	ug/l	EPA .200.8	2	10/11/2019 18:37 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000039 : classroom 111-bubbler 05/07/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 18:39 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000040 : classroom 42-sink 05/07/2019 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.7	ug/l	EPA .200.8	2	10/11/2019 18:42 BJ



MARTEL NO. 40829 000041 : classroom 42-bubbler CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/07/2019 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.18	ug/l	EPA .200.8	2	10/11/2019 18:54 BJ

MARTEL NO. 40829 000042 : classroom 113-sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/07/2019 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.13	ug/l	EPA .200.8	2	10/11/2019 19:06 BJ

MARTEL NO. 40829 000043 : classroom 113-bubbler CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/07/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.87	ug/l	EPA .200.8	2	10/11/2019 19:09 BJ

MARTEL NO. 40829 000044 : classroom 112-sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/07/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.71	ug/l	EPA .200.8	2	10/11/2019 19:11 BJ

MARTEL NO. 40829 000045 : classroom 112-bubbler CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/07/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 19:14 BJ

MARTEL NO. 40829 000046 : corridor-water fountain CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/07/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 19:16 BJ

MARTEL NO. 40829 000047 : classroom 114-sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/07/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.03	ug/l	EPA .200.8	2	10/11/2019 19:18 BJ

MARTEL NO. 40829 000048 : classroom 114-bubbler CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/07/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 19:21 BJ



MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 115-sink Sample Date/Time 05/07/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.64	ug/l	EPA .200.8	2	10/11/2019 19:23 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 115-bubbler Sample Date/Time 05/07/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 19:26 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 116-sink Sample Date/Time 05/07/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.11	ug/l	EPA .200.8	2	10/11/2019 19:36 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 116-bubbler Sample Date/Time 05/07/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.79	ug/l	EPA .200.8	2	10/11/2019 19:41 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 118-sink Sample Date/Time 05/07/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.1	ug/l	EPA .200.8	2	10/11/2019 19:43 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 118-bubbler Sample Date/Time 05/07/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	69.8	ug/l*	EPA .200.8	2	10/11/2019 19:46 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 205-sink Sample Date/Time 05/07/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.19	ug/l	EPA .200.8	2	10/11/2019 19:48 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : corridor-water fountain Sample Date/Time 05/07/2019 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 19:50 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40829	000057	: classroom 119-sink	05/07/2019 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.17	ug/l	EPA .200.8	2	10/11/2019 19:53 BJ	
40829	000058	: classroom 119-water fountain	05/07/2019 05:21			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 19:55 BJ	
40829	000059	: classroom 120-sink	05/07/2019 05:22			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 19:58 BJ	
40829	000060	: classroom 120-water fountain	05/07/2019 05:23			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 20:00 BJ	
40829	000061	: classroom 121-sink	05/07/2019 05:24			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 20:13 BJ	
40829	000062	: classroom 121-bubbler	05/07/2019 05:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 20:25 BJ	
40829	000063	: classroom 123-sink	05/07/2019 05:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 20:27 BJ	
40829	000064	: classroom 123-bubbler	05/07/2019 05:27			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 20:30 BJ	



MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 124-sink Sample Date/Time 05/07/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.99	ug/l	EPA .200.8	2	10/11/2019 20:32 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 124-bubbler Sample Date/Time 05/07/2019 05:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	28.0	ug/l*	EPA .200.8	2	10/11/2019 20:35 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 117-sink Sample Date/Time 05/07/2019 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.26	ug/l	EPA .200.8	2	10/11/2019 20:37 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 117-bubbler Sample Date/Time 05/07/2019 05:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.67	ug/l	EPA .200.8	2	10/11/2019 20:40 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : corridor-water fountain Sample Date/Time 05/07/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 20:42 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 122-sink Sample Date/Time 05/07/2019 05:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	38.2	ug/l*	EPA .200.8	2	10/11/2019 20:45 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 122-water fountain Sample Date/Time 05/07/2019 05:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.09	ug/l	EPA .200.8	2	10/11/2019 20:55 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 125-sink Sample Date/Time 05/07/2019 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.81	ug/l	EPA .200.8	2	10/11/2019 21:00 BJ



Certificate of Analysis

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : classroom 125-water fountain Sample Date/Time 05/07/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.49	ug/l	EPA .200.8	2	10/11/2019 21:02 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : CR 20 -sink Sample Date/Time 05/07/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.85	ug/l	EPA .200.8	2	10/11/2019 21:09 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : CR 20 -bubbler Sample Date/Time 05/07/2019 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.02	ug/l	EPA .200.8	2	10/11/2019 21:12 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : activity room-ice maker Sample Date/Time 05/07/2019 05:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 21:14 BJ

MARTEL NO. 40829 CLIENT SAMPLE IDENTIFICATION : 108 Prekindergarten-ice maker Sample Date/Time 05/07/2019 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	10/11/2019 21:17 BJ

Page 10 OF 10

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com


stdl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

Martel Laboratories JDS Inc.

CHARPS

Page 10 OF 10

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054

Questions, comments or concerns? Contact your Martel representative or email martel@martellabs.com

10/14/2019