



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Attention:

Report for Lab No: 48206.
Retest samples picked up by Martel on 12/18/2019.
Project Identification: MD HB 270
School: 06 Indian Head ES.

Monday, February 3, 2020

Certificate of Analysis

FINAL

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48206 000004	IHES-4-KS: kitchen 2 comp sink-2 comp sink on left	12/03/2019 06:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.74	ug/l	EPA .200.8	2	01/24/2020 12:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48206 000012	IHES-12-CR: planning Special Education-sink	12/03/2019 06:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	206	ug/l*	EPA .200.8	2	01/24/2020 12:18 BJ

Page 1 OF 1

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager