



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Monday, February 10, 2020

Certificate of Analysis

FINAL

Attention:

Report for Lab No: 48255.
Retest samples picked up by Martel on 12/18/2019.
Project Identification: MD HB 270
School: 55 McDonough High School PSC 08.009.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48255 000011	Kitchen: water fountain-DF	12/06/2019 06:45
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	6.78 ug/l EPA .200.8 2	02/07/2020 13:30 BJ
48255 000033	FCS-1/ home ec: sink-HF	12/06/2019 06:47
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.16 ug/l EPA .200.8 2	02/07/2020 13:33 BJ
48255 000037	FCS-1/ home ec: sink-HF	12/06/2019 06:48
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.74 ug/l EPA .200.8 2	02/07/2020 13:35 BJ
48255 000038	FCS-1/ home ec: sink-HF	12/06/2019 06:52
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	22.5 ug/l* EPA .200.8 2	02/07/2020 13:38 BJ
48255 000039	corridor: water fountain-DF	12/06/2019 06:55
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.36 ug/l EPA .200.8 2	02/07/2020 13:41 BJ
48255 000040	corridor: water fountain -DF	12/06/2019 06:58
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.68 ug/l EPA .200.8 2	02/07/2020 13:43 BJ



Certificate of Analysis

Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

Page 2 OF 2
02/10/2020
stdl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager