


MARTEL



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Attention:

Report for Lab No: 48209.
Retest samples picked up by Martel on 12/18/2019.
Project Identification: MD HB 270
School: 09 Arthur Middleton Elementary School PSC 08.011

Monday, February 10, 2020

Certificate of Analysis FINAL

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48209 000003	AMES-3-OT: kitchen kettle-kettle	12/10/2019 06:50
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	41.6 ug/l* EPA .200.8 2	02/07/2020 18:53 BJ
48209 000017	AMES-16-CF: Science B108-sink	12/10/2019 06:52
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	29.2 ug/l* EPA .200.8 2	02/07/2020 18:56 BJ
48209 000019	AMES-18-CR: Science B108-sink	12/10/2019 06:54
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	17.4 ug/l EPA .200.8 2	02/07/2020 18:58 BJ
48209 000024	AMES-23-DF: Special Education D106-bubbler	12/10/2019 06:56
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	21.6 ug/l* EPA .200.8 2	02/07/2020 19:01 BJ
48209 000030	AMES-29-CF: 2nd Grade-sink	12/10/2019 06:58
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	38.7 ug/l* EPA .200.8 2	02/07/2020 19:03 BJ
48209 000032	AMES-31-CR: 2nd Grade-sink	12/10/2019 07:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	14.8 ug/l EPA .200.8 2	02/07/2020 19:05 BJ



Certificate of Analysis

Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

Page 2 OF 2
02/10/2020
stddl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager