



**Charles County Public Schools**

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

Monday, July 29, 2019

**Certificate of Analysis  
FINAL**

**Attention:**

Report for Lab No: 40809.  
Samples picked up by Martel on 4/13/19.  
Project Identification: MD HB 270  
School: 10 Walter J. Mitchell Elementary.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000001	WMES-1-DF: Gym-water fountain	04/02/2019 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 16:59 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000002	WMES-2-DF: Gym-water fountain	04/02/2019 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:02 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000003	WMES-3-CF: A109-sink	04/02/2019 05:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:04 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000004	WMES-4-DF: A109-bubbler	04/02/2019 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	13.5	ug/l	EPA .200.8	2	07/22/2019 17:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000005	WMES-5-CF: A108-sink	04/02/2019 05:06			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.24	ug/l	EPA .200.8	2	07/22/2019 17:09 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000006	WMES-6-DF: A108-bubbler	04/02/2019 05:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:18 BJ



MARTEL NO. 40809      000007      CLIENT SAMPLE IDENTIFICATION WMES-7-CF: A107-sink      Sample Date/Time 04/02/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:23 BJ

MARTEL NO. 40809      000008      CLIENT SAMPLE IDENTIFICATION WMES-8-DF: A107-bubbler      Sample Date/Time 04/02/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:26 BJ

MARTEL NO. 40809      000009      CLIENT SAMPLE IDENTIFICATION WMES-9-DF: corridor-water fountain      Sample Date/Time 04/02/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:28 BJ

MARTEL NO. 40809      000010      CLIENT SAMPLE IDENTIFICATION WMES-10-CF: A106-sink      Sample Date/Time 04/02/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.37	ug/l	EPA .200.8	2	07/22/2019 17:30 BJ

MARTEL NO. 40809      000011      CLIENT SAMPLE IDENTIFICATION WMES-11-DF: A106-bubbler      Sample Date/Time 04/02/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:33 BJ

MARTEL NO. 40809      000012      CLIENT SAMPLE IDENTIFICATION WMES-12-CF: A105 -sink      Sample Date/Time 04/02/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:35 BJ

MARTEL NO. 40809      000013      CLIENT SAMPLE IDENTIFICATION WMES-13-DF: A105 -bubbler      Sample Date/Time 04/02/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 17:38 BJ

MARTEL NO. 40809      000014      CLIENT SAMPLE IDENTIFICATION WMES-14-CF: A104-sink      Sample Date/Time 04/02/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	18.9	ug/l	EPA .200.8	2	07/22/2019 17:40 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000015	WMES-15-DF: A104-bubbler	04/02/2019 05:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.80	ug/l	EPA .200.8	2	07/22/2019 17:43 BJ	
40809	000016	WMES-16-CF: A103-sink	04/02/2019 05:28			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	6.34	ug/l	EPA .200.8	2	07/22/2019 17:55 BJ	
40809	000017	WMES-17-DF: A103-bubbler	04/02/2019 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.37	ug/l	EPA .200.8	2	07/22/2019 18:07 BJ	
40809	000018	WMES-18-CF: A102-sink	04/02/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:09 BJ	
40809	000019	WMES-19-DF: A102-bubbler	04/02/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:12 BJ	
40809	000020	WMES-20-CF: A101-sink	04/02/2019 05:36			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:14 BJ	
40809	000021	WMES-21-DF: A101 -bubbler	04/02/2019 05:38			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:16 BJ	
40809	000022	WMES-22-DF: corridor-water fountain	04/02/2019 05:39			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:19 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000023	WMES-23-DF: cafeteria-water fountain	04/02/2019 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:21 BJ	
40809	000024	WMES-24-IM: kitchen-ice maker	04/02/2019 05:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:24 BJ	
40809	000025	WMES-25-OT: kitchen-kettle	04/02/2019 05:50			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	36.0	ug/l*	EPA .200.8	2	07/22/2019 18:26 BJ	
40809	000026	WMES-26-KS: kitchen-2 comp sink	04/02/2019 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:36 BJ	
40809	000027	WMES-27-KS: kitchen-3 comp sink left	04/02/2019 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.53	ug/l	EPA .200.8	2	07/22/2019 18:41 BJ	
40809	000028	WMES-28-KS: kitchen-3 comp sink right	04/02/2019 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.11	ug/l	EPA .200.8	2	07/22/2019 18:43 BJ	
40809	000029	WMES-29-DF: corridor-water fountain	04/02/2019 05:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:46 BJ	
40809	000030	WMES-30-NO: nurse office-sink	04/02/2019 05:06			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:48 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000031	WMES-31-DF: corridor-water fountain	04/02/2019 05:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/22/2019 18:51 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000032	WMES-32-CF: B110-sink	04/02/2019 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	75.5	ug/l*	EPA .200.8	2	06/11/2019 10:26 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000033	WMES-33-DF: B110-bubbler	04/02/2019 05:12			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	22.9	ug/l*	EPA .200.8	2	06/11/2019 10:36 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000034	WMES-34-CF: B109-sink	04/02/2019 05:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	23.1	ug/l*	EPA .200.8	2	06/11/2019 10:41 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000035	WMES-35-DF: B109-bubbler	04/02/2019 05:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.64	ug/l	EPA .200.8	2	07/22/2019 18:53 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000036	WMES-36-CF: B108-sink	04/02/2019 05:18			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	15.6	ug/l	EPA .200.8	2	06/11/2019 10:44 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000037	WMES-37-DF: B108-bubbler	04/02/2019 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	92.8	ug/l*	EPA .200.8	2	06/11/2019 10:46 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000038	WMES-38-CF: B107-sink	04/02/2019 05:22			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	68.3	ug/l*	EPA .200.8	2	07/22/2019 18:56 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000039	WMES-39-DF: B107-bubbler	04/02/2019 05:24			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.77	ug/l	EPA .200.8	2	07/22/2019 18:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000040	WMES-40-CF: B106-sink	04/02/2019 05:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.04	ug/l	EPA .200.8	2	07/22/2019 19:00 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000041	WMES-41-DF: B106-bubbler	04/02/2019 05:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 09:44 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000042	WMES-42-CF: B105-sink	04/02/2019 05:28			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.11	ug/l	EPA .200.8	2	07/25/2019 09:55 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000043	WMES-43-Df: B105-bubbler	04/02/2019 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 09:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000044	WMES-44-DF: corridor-water fountain	04/02/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 10:00 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000045	WMES-45-CF: B104-sink	04/02/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.13	ug/l	EPA .200.8	2	07/25/2019 10:03 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000046	WMES-46-DF: B104-bubbler	04/02/2019 05:36			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 10:05 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000047	WMES-47-CF: B103-sink	04/02/2019 05:37			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	25.0	ug/l*	EPA .200.8	2	07/25/2019 10:07 BJ	
40809	000048	WMES-48-DF: B103-bubbler	04/02/2019 05:38			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	21.1	ug/l*	EPA .200.8	2	07/25/2019 10:10 BJ	
40809	000049	WMES-49-CF: B103-sink	04/02/2019 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	18.5	ug/l	EPA .200.8	2	07/25/2019 10:12 BJ	
40809	000050	WMES-50-DF: B103-bubbler	04/02/2019 05:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.11	ug/l	EPA .200.8	2	07/25/2019 10:15 BJ	
40809	000051	WMES-51-CF: B102-sink	04/02/2019 05:47			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.09	ug/l	EPA .200.8	2	07/25/2019 10:25 BJ	
40809	000052	WMES-52-DF: B102-bubbler	04/02/2019 05:49			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.96	ug/l	EPA .200.8	2	07/25/2019 10:30 BJ	
40809	000053	WMES-53-CF: B102-sink	04/02/2019 05:50			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	14.5	ug/l	EPA .200.8	2	07/25/2019 10:32 BJ	
40809	000054	WMES-54-DF: B102-bubbler	04/02/2019 06:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 10:34 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000055	WMES-55-CF: B101-sink	04/02/2019 06:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.89	ug/l	EPA .200.8	2	07/25/2019 10:37 BJ
40809 000056	WMES-56-DF: B101-bubbler	04/02/2019 06:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.1	ug/l	EPA .200.8	2	07/25/2019 10:39 BJ
40809 000057	WMES-57-DF: library-water fountain	04/02/2019 06:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 10:42 BJ
40809 000058	WMES-58-DF: corridor-water fountain	04/02/2019 06:12			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.14	ug/l	EPA .200.8	2	07/25/2019 10:44 BJ
40809 000059	WMES-59-CF: C110-sink	04/02/2019 06:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	31.6	ug/l*	EPA .200.8	2	07/25/2019 10:46 BJ
40809 000060	WMES-60-DF: C110-bubbler	04/02/2019 06:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.6	ug/l*	EPA .200.8	2	07/25/2019 10:49 BJ
40809 000061	WMES-61-CF: C109-sink	04/02/2019 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	31.5	ug/l*	EPA .200.8	2	07/25/2019 11:01 BJ
40809 000062	WMES-62-DF: C109-bubbler	04/02/2019 05:01			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.21	ug/l	EPA .200.8	2	06/11/2019 10:48 BJ





MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000063	WMES-63-CF: C108-sink	04/02/2019 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	17.1	ug/l	EPA .200.8	2	06/11/2019 10:51 BJ
40809 000064	WMES-64-DF: C108-bubbler	04/02/2019 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.4	ug/l	EPA .200.8	2	06/11/2019 10:53 BJ
40809 000065	WMES-65-CF: C107-sink	04/02/2019 05:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	256	ug/l*	EPA .200.8	2	07/25/2019 11:13 BJ
40809 000066	WMES-66-DF: C107-bubbler	04/02/2019 05:07			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	224	ug/l*	EPA .200.8	2	06/11/2019 10:56 BJ
40809 000067	WMES-67-CF: C106-sink	04/02/2019 05:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	27.2	ug/l*	EPA .200.8	2	07/25/2019 11:15 BJ
40809 000068	WMES-68-DF: C106-bubbler	04/02/2019 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.5	ug/l*	EPA .200.8	2	07/25/2019 11:18 BJ
40809 000069	WMES-69-CF: C105-sink	04/02/2019 05:11			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	24.8	ug/l*	EPA .200.8	2	07/25/2019 11:20 BJ
40809 000070	WMES-70-DF: C105-bubbler	04/02/2019 05:12			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.26	ug/l	EPA .200.8	2	07/25/2019 11:23 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40809 000071	WMES-71-CF: C105-sink	04/02/2019 05:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	13.3	ug/l	EPA .200.8	2	07/25/2019 11:25 BJ
40809 000072	WMES-72-DF: C105-bubbler	04/02/2019 05:16			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.18	ug/l	EPA .200.8	2	07/25/2019 11:27 BJ
40809 000073	WMES-73-DF: corridor-water fountain	04/02/2019 05:18			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 11:30 BJ
40809 000074	WMES-74-CF: C104-sink	04/02/2019 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.57	ug/l	EPA .200.8	2	07/25/2019 11:32 BJ
40809 000075	WMES-75-DF: C104-bubbler	04/02/2019 05:22			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.07	ug/l	EPA .200.8	2	07/25/2019 11:42 BJ
40809 000076	WMES-76-CF: C104-sink	04/02/2019 05:24			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	16.6	ug/l	EPA .200.8	2	07/25/2019 11:47 BJ
40809 000077	WMES-77-DF: C104-bubbler	04/02/2019 05:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.01	ug/l	EPA .200.8	2	07/25/2019 11:49 BJ
40809 000078	WMES-78-CF: C103-sink	04/02/2019 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.03	ug/l	EPA .200.8	2	07/25/2019 11:51 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000079	WMES-79-DF: C103-bubbler	04/02/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	8.33	ug/l	EPA .200.8	2	07/25/2019 11:54 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000080	WMES-80-CF: C102-sink	04/02/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.13	ug/l	EPA .200.8	2	07/25/2019 11:56 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000081	WMES-81-DF: C102-bubbler	04/02/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 11:59 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000082	WMES-82-CF: C101-sink	04/02/2019 05:36			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	21.1	ug/l*	EPA .200.8	2	07/25/2019 12:01 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000083	WMES-83-DF: C101-bubbler	04/02/2019 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 12:04 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000084	WMES-84-KS: Kitchen next to dishwashe	04/02/2019 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/25/2019 12:06 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000085	WMES-85-DF: Exterior on Gym	04/02/2019 05:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	506	ug/l*	EPA .200.8	2	06/11/2019 10:58 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40809	000086	WMES-86-DF: Exterior on B-Pod	04/02/2019 05:47			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	454	ug/l*	EPA .200.8	2	06/11/2019 11:01 BJ	



---

**Martel Laboratories *JDS* Inc.**

Page 12 OF 12

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

07/29/2019

stddl.frx

---

**Notes and references:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager