



**Charles County Public Schools**

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

Monday, September 16, 2019

***Certificate of Analysis***  
**FINAL**

**Attention:**

Report for Lab No: 40839.  
Samples picked up by Martel on April 10 and June 25, 2019.  
Project Identification: MD HB 270  
School: 75 Nanjemoy Creek.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40839 000001	pavillion: water fountain-DF, flushed	04/10/2019 13:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/27/2019 11:20 BJ
40839 000002	pavillion lounge: kitchen sink-KS, flushed	04/10/2019 13:05
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/27/2019 11:25 BJ
40839 000003	BS office bathroom: water fountain-DF, flushed	04/10/2019 13:10
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/27/2019 11:27 BJ
40839 000004	BS office bathroom: water fountain-DF, flushed	04/10/2019 13:15
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/27/2019 11:30 BJ
40839 000005	pavillion-water fountain	06/25/2019 07:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	08/27/2019 11:32 BJ
40839 000006	pavillion lounge-kitchen sink	06/25/2019 07:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	08/27/2019 11:35 BJ



---

MARTEL NO. 40839	000007	CLIENT SAMPLE IDENTIFICATION BS office bathroom, fountain				Sample Date/Time 06/25/2019 07:04
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA 200.8	2	08/27/2019 11:37 BJ

---

MARTEL NO. 40839	000008	CLIENT SAMPLE IDENTIFICATION BS office bathroom-fountain				Sample Date/Time 06/25/2019 07:04
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA 200.8	2	08/27/2019 11:39 BJ

---

Page 2 OF 2


1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stddl.frx

**Notes and references:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager