

MARTEL



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Attention:

Report for Lab No: 40810.
Samples picked up by Martel on 4/13/19.
Project Identification: MD HB 270
School: Mary B. Neal Elementary.

Tuesday, August 6, 2019

Certificate of Analysis FINAL

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40810 000001	WNES-1-KS: Kitchen-Sink	04/03/2019 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	2.33 ug/l EPA .200.8	2 08/02/2019 09:53 BJ
40810 000002	WNES-2-KS: Kitchen 2 comp -Sink	04/03/2019 05:01
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	2.93 ug/l EPA .200.8	2 08/02/2019 10:04 BJ
40810 000003	WNES-3-IM: Kitchen-Ice Machine	04/03/2019 05:02
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 08/02/2019 16:21 BJ
40810 000004	WNES-4-KS: Kitchen 3 comp -Sink on Left	04/03/2019 05:03
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 08/02/2019 10:09 BJ
40810 000005	WNES-5-KS: Kitchen 3 comp -sink on Right	04/03/2019 05:05
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 08/02/2019 10:12 BJ
40810 000006	WNES-6-DF: Corridor-water fountain on left	04/03/2019 05:07
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 08/02/2019 10:14 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000007	WNES-7-DF: Corridor-water fountain on right	04/03/2019 05:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000008	WNES-8-DF: Corridor-water fountain on left	04/03/2019 05:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:19 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000009	WNES-9-DF: Corridor-water fountain on right	04/03/2019 05:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:21 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000010	WNES-10-TL: Teacher lounge-sink	04/03/2019 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000011	WNES-11-CF: Art room B105-sink	04/03/2019 05:12			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:34 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000012	WNES-12-DF: Art room B105-bubbler	04/03/2019 05:13			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:39 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000013	WNES-13-CF: Classroom B101-sink	04/03/2019 05:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.44	ug/l	EPA .200.8	2	08/02/2019 10:41 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000014	WNES-14-DF: Classroom B101-bubbler	04/03/2019 05:13			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:43 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000015	WNES-15-CF: Classroom B107-sink	04/03/2019 05:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.61	ug/l	EPA .200.8	2	08/02/2019 10:46 BJ	
40810	000016	WNES-16-DF: Classroom B107-bubbler	04/03/2019 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:48 BJ	
40810	000017	WNES-17-DF: Main Office Hallway-Water fountain on left	04/03/2019 05:01			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:51 BJ	
40810	000018	WNES-18-DF: Main Office Hallway-water fountain on right	04/03/2019 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:53 BJ	
40810	000019	WNES-19-NO: Nurse office-sink	04/03/2019 05:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 10:55 BJ	
40810	000020	WNES-20-NO: Nurse Office A124-sink	04/03/2019 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	14.0	ug/l	EPA .200.8	2	08/02/2019 10:58 BJ	
40810	000021	WNES-21-DF: Corridor-water fountain	04/03/2019 05:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 11:10 BJ	
40810	000022	WNES-22-CF: Classroom D111-sink	04/03/2019 05:06			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 11:22 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40810 000023	WNES-23-DF: Classroom D111-bubbler	04/03/2019 05:07
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	4.14 ug/l EPA .200.8 2	08/02/2019 11:25 BJ
40810 000024	WNES-24-CF: Classroom D124-sink	04/03/2019 05:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.82 ug/l EPA .200.8 2	08/02/2019 11:27 BJ
40810 000025	WNES-25-DF: Classroom D124-bubbler	04/03/2019 05:10
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/02/2019 11:29 BJ
40810 000026	WNES-26-CF: Classroom D113-sink	04/03/2019 05:11
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	4.60 ug/l EPA .200.8 2	08/02/2019 11:32 BJ
40810 000027	WNES-27-DF: Classroom D113-bubbler	04/03/2019 05:12
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/02/2019 11:34 BJ
40810 000028	WNES-28-CF: Classroom D115-sink	04/03/2019 05:14
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	52.0 ug/l* EPA .200.8 2	06/11/2019 09:33 BJ
40810 000029	WNES-29-DF: Classroom D115-bubbler	04/03/2019 05:15
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	8.89 ug/l EPA .200.8 2	08/02/2019 11:36 BJ
40810 000030	WNES-30-CF: Classroom D122-sink	04/03/2019 05:16
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	20.3 ug/l EPA .200.8 2	08/02/2019 11:39 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000031	WNES-31-DF: Classroom D122-bubbler	04/03/2019 05:18			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 11:51 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000032	WNES-32-CF: Classroom D120-sink	04/03/2019 05:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	25.5	ug/l*	EPA .200.8	2	06/11/2019 09:35 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000033	WNES-33-DF: Classroom D120-bubbler	04/03/2019 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.39	ug/l	EPA .200.8	2	06/11/2019 09:37 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000034	WNES-34-CF: Classroom D117-sink	04/03/2019 05:22			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	16.3	ug/l	EPA .200.8	2	08/02/2019 11:56 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000035	WNES-35-DF: Classroom D117-bubbler	04/03/2019 05:24			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 11:58 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000036	WNES-36-CF: Classroom E133-sink	04/03/2019 05:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:00 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000037	WNES-37-DF: Classroom E133-bubbler	04/03/2019 05:27			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:03 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000038	WNES-38-CF: Classroom E106 -sink	04/03/2019 05:28			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.10	ug/l	EPA .200.8	2	08/02/2019 12:05 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000039	WNES-39-DF: Classroom E106 -bubbler	04/03/2019 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:08 BJ	
40810	000040	WNES-40-CF: Classroom E130-sink	04/03/2019 05:31			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.14	ug/l	EPA .200.8	2	08/02/2019 12:10 BJ	
40810	000041	WNES-41-DF: Classroom E130-bubbler	04/03/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:27 BJ	
40810	000042	WNES-42-CF: Classroom E112-sink	04/03/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.52	ug/l	EPA .200.8	2	08/02/2019 12:40 BJ	
40810	000043	WNES-43-DF: Classroom E112-bubbler	04/03/2019 05:35			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:42 BJ	
40810	000044	WNES-44-CF: Classroom E127-sink	04/03/2019 05:37			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:44 BJ	
40810	000045	WNES-45-DF: Classroom E127-bubbler	04/03/2019 05:41			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:47 BJ	
40810	000046	WNES-46-CF: Classroom E114-sink	04/03/2019 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:49 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810 000047	WNES-47-DF: Classroom E114-bubbler		04/03/2019 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:52 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810 000048	WNES-48-CF: Classroom E124-sink		04/03/2019 05:01			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:54 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810 000049	WNES-49-DF: Classroom E124-bubbler		04/03/2019 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 12:56 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810 000050	Classroom E117-sink		04/03/2019 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.71	ug/l	EPA 200.8	2	08/02/2019 12:59 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810 000051	WNES-51-DF: Classroom E117-bubbler		04/03/2019 05:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 13:09 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810 000052	WNES-52-CF: Classroom E121-sink		04/03/2019 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 13:14 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810 000053	WNES-53-DF: Classroom E121-bubbler		04/03/2019 05:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 13:16 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810 000054	WNES-54-DF: Corridor-water fountain		04/03/2019 05:06			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 13:19 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40810 000055	WNES-54-CF: Classroom G207-sink	04/03/2019 05:08
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.83 ug/l EPA .200.8 2	08/02/2019 13:21 BJ
40810 000056	WNES-55-DF: Classroom G207-bubbler	04/03/2019 05:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/02/2019 13:23 BJ
40810 000057	WNES-56-CF: Classroom G226-sink	04/03/2019 05:10
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/02/2019 13:26 BJ
40810 000058	WNES-57-DF: Classroom G226-bubbler	04/03/2019 05:12
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/02/2019 13:28 BJ
40810 000059	WNES-58-CF: Classroom G224-sink	04/03/2019 05:13
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.06 ug/l EPA .200.8 2	08/02/2019 13:31 BJ
40810 000060	WNES-59-DF: Classroom G224-bubbler	04/03/2019 05:14
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/02/2019 13:33 BJ
40810 000061	WNES-60-CF: Classroom G209-sink	04/03/2019 05:15
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.00 ug/l EPA .200.8 2	08/02/2019 16:25 BJ
40810 000062	WNES-61-DF: Classroom G209-bubbler	04/03/2019 05:16
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	08/02/2019 16:38 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000063	WNES-62-CF: Classroom G211-sink	04/03/2019 05:17			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.72	ug/l	EPA .200.8	2	08/02/2019 16:40 BJ	
40810	000064	WNES-63-DF: Classroom G211-bubbler	04/03/2019 05:18			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 16:43 BJ	
40810	000065	WNES-64-CF: Classroom G222-sink	04/03/2019 05:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.81	ug/l	EPA .200.8	2	08/02/2019 16:45 BJ	
40810	000066	WNES-65-DF: Classroom G222-bubbler	04/03/2019 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 14:07 BJ	
40810	000067	WNES-66-CF: Classroom G220-sink	04/03/2019 05:21			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.78	ug/l	EPA .200.8	2	08/02/2019 14:10 BJ	
40810	000068	WNES-67-DF: Classroom G220-bubbler	04/03/2019 05:22			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 14:12 BJ	
40810	000069	WNES-68-CF: Classroom G213-sink	04/03/2019 05:23			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.25	ug/l	EPA .200.8	2	08/02/2019 14:15 BJ	
40810	000070	WNES-69-DF: Classroom G213-bubbler	04/03/2019 05:24			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 14:17 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000071	WNES-70-CF: Classroom G215-sink	04/03/2019 05:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.33	ug/l	EPA .200.8	2	08/02/2019 14:27 BJ	
40810	000072	WNES-71-DF: Classroom G215-bubbler	04/03/2019 05:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 14:32 BJ	
40810	000073	WNES-72-CF: Classroom G218-sink	04/03/2019 05:27			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.80	ug/l	EPA .200.8	2	08/02/2019 14:35 BJ	
40810	000074	WNES-73-DF: Classroom G218-bubbler	04/03/2019 05:28			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 14:37 BJ	
40810	000075	WNES-74-DF: Corridor-water fountain	04/03/2019 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 14:39 BJ	
40810	000076	WNES-75-CF: Classroom F208-sink	04/03/2019 05:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.83	ug/l	EPA .200.8	2	08/02/2019 14:42 BJ	
40810	000077	WNES-76-DF: Classroom F208-bubbler	04/03/2019 05:17			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 14:44 BJ	
40810	000078	WNES-77-CF: Classroom F223-sink	04/03/2019 05:17			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	6.48	ug/l	EPA .200.8	2	08/02/2019 14:47 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40810	000079	WNES-78-DF: Classroom F223-bubbler	04/03/2019 05:18			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 14:49 BJ	
40810	000080	WNES-79-CF: Classroom F221-sink	04/03/2019 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.80	ug/l	EPA .200.8	2	08/02/2019 14:52 BJ	
40810	000081	WNES-80-DF: Classroom F221-bubbler	04/03/2019 05:21			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 15:04 BJ	
40810	000082	WNES-81-CF: Classroom F210-sink	04/03/2019 05:23			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 15:16 BJ	
40810	000083	WNES-82-DF: Classroom F210-bubbler	04/03/2019 05:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 15:19 BJ	
40810	000084	WNES-83-CF: Classroom F212-sink	04/03/2019 05:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.46	ug/l	EPA .200.8	2	08/02/2019 15:21 BJ	
40810	000085	WNES-84-DF: Classroom F212-bubbler	04/03/2019 05:27			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 15:24 BJ	
40810	000086	WNES-85-CF: Classroom F219-sink	04/03/2019 05:28			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	9.49	ug/l	EPA .200.8	2	08/02/2019 15:26 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000087	WNES-86-DF: Classroom F219-bubbler	04/03/2019 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 15:28 BJ


MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000088	WNES-87-CF: Classroom F217-sink	04/03/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.98	ug/l	EPA .200.8	2	08/02/2019 15:31 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000089	WNES-88-DF: Classroom F217-bubbler	04/03/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 15:33 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000090	WNES-89-CF: Classroom F214-sink	04/03/2019 05:35			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.26	ug/l	EPA .200.8	2	08/02/2019 15:36 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000091	WNES-90-DF: Classroom F214-bubbler	04/03/2019 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 15:46 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40810 000092	WNES-92-IM Nurse Office Ice Maker	04/03/2019 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/02/2019 15:51 BJ



Martel Laboratories JDS Inc.

Page 13 OF 13

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

08/06/2019
stddl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager