


# MARTEL



## Charles County Public Schools

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

### Attention:

Report for Lab No: 48236.  
Retest samples picked up by Martel on 12/18/2019.  
Project Identification: MD HB 270  
School: 36 Smallwood Middle School PSC 08.005.

Monday, February 10, 2020

## Certificate of Analysis FINAL

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48236 000014	ESMS-14-CR: Classroom 115-sink	12/03/2019 06:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	49.1	ug/l*	EPA .200.8	2	02/04/2020 13:08 CSG

Page 1 OF 1

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

### Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager



**36 General Smallwood Middle School**

**PSC #08.005**

**4990 Indian Head Highway**

**Indian Head, MD 20640**

**School Dude Work Order #17303**

<b>Sample Location Identification # (School- ID-Location on map)</b>	<b>Fixture location / Room #</b>	<b>Fixture Type</b>	<b>ID</b>	<b>Sample Floor Plan Id #</b>
ESMS-14-CR	Classroom 115	sink	CR	14