


# MARTEL



## Charles County Public Schools

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

### Attention:

Report for Lab No: 40840.  
Samples picked up by Martel on 5/22/19.  
Project Identification: MD HB 270  
School: 60 St. Charles High School.

Monday, November 4, 2019

## Certificate of Analysis FINAL

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40840 000001	cafeteria (L): water fountain -DF	05/22/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	11/01/2019 23:35 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40840 000002	cafeteria R: water fountain -DF	05/22/2019 05:01
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	11/01/2019 23:47 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40840 000003	kitchen: 2 comp sink-KS	05/22/2019 05:02
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	11/01/2019 23:50 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40840 000004	kitchen: island sink across form G110-KS	05/22/2019 05:03
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	11/01/2019 23:52 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40840 000005	kitchen: island sink by oven-KS	05/22/2019 05:04
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	11/01/2019 23:54 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40840 000006	kitchen: island sink at freezer-KS	05/22/2019 05:05
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	11/01/2019 23:57 BJ



## Certificate of Analysis

MARTEL NO. 40840 000007 CLIENT SAMPLE IDENTIFICATION kitchen: kettle -OT Sample Date/Time 05/22/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/01/2019 23:59 BJ

MARTEL NO. 40840 000008 CLIENT SAMPLE IDENTIFICATION kitchen: ice maker-IM Sample Date/Time 05/22/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:02 BJ

MARTEL NO. 40840 000009 CLIENT SAMPLE IDENTIFICATION kitchen: 3 comp sink L-KS Sample Date/Time 05/22/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:04 BJ

MARTEL NO. 40840 000010 CLIENT SAMPLE IDENTIFICATION kitchen: 3 comp sink R-KS Sample Date/Time 05/22/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:07 BJ

MARTEL NO. 40840 000011 CLIENT SAMPLE IDENTIFICATION boys locker room: water fountain -DF Sample Date/Time 05/22/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:17 BJ

MARTEL NO. 40840 000012 CLIENT SAMPLE IDENTIFICATION boys locker room: water fountain -DF Sample Date/Time 05/22/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:22 BJ

MARTEL NO. 40840 000013 CLIENT SAMPLE IDENTIFICATION training room: sink-OT Sample Date/Time 05/22/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:24 BJ

MARTEL NO. 40840 000014 CLIENT SAMPLE IDENTIFICATION training room: ice machine-IM Sample Date/Time 05/22/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.41	ug/l	EPA .200.8	2	11/02/2019 00:26 BJ



## Certificate of Analysis

MARTEL NO. 40840 000015 CLIENT SAMPLE IDENTIFICATION girls locker room: water fountain -DF Sample Date/Time 05/22/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:29 BJ

MARTEL NO. 40840 000016 CLIENT SAMPLE IDENTIFICATION girls locker room: water fountain -DF Sample Date/Time 05/22/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:31 BJ

MARTEL NO. 40840 000017 CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF Sample Date/Time 05/22/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:34 BJ

MARTEL NO. 40840 000018 CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF Sample Date/Time 05/22/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:36 BJ

MARTEL NO. 40840 000019 CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF Sample Date/Time 05/22/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:39 BJ

MARTEL NO. 40840 000020 CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF Sample Date/Time 05/22/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:41 BJ

MARTEL NO. 40840 000021 CLIENT SAMPLE IDENTIFICATION concessions: sink-CR Sample Date/Time 05/22/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 00:53 BJ

MARTEL NO. 40840 000022 CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF Sample Date/Time 05/22/2019 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:06 BJ



MARTEL NO. 40840 000023 CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF Sample Date/Time 05/22/2019 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:08 BJ

MARTEL NO. 40840 000024 CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF Sample Date/Time 05/22/2019 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:10 BJ

MARTEL NO. 40840 000025 CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF Sample Date/Time 05/22/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:13 BJ

MARTEL NO. 40840 000026 CLIENT SAMPLE IDENTIFICATION nurse office: sink-NO Sample Date/Time 05/22/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:15 BJ

MARTEL NO. 40840 000027 CLIENT SAMPLE IDENTIFICATION nurse office: sink-NO Sample Date/Time 05/22/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:18 BJ

MARTEL NO. 40840 000028 CLIENT SAMPLE IDENTIFICATION home ec: sink-HE Sample Date/Time 05/22/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:20 BJ

MARTEL NO. 40840 000029 CLIENT SAMPLE IDENTIFICATION home ec L: sink-HE Sample Date/Time 05/22/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:23 BJ

MARTEL NO. 40840 000030 CLIENT SAMPLE IDENTIFICATION home ec R: sink-HE Sample Date/Time 05/22/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:25 BJ



MARTEL NO. 40840      000031      CLIENT SAMPLE IDENTIFICATION home ec L: sink-HE      Sample Date/Time 05/22/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:35 BJ

MARTEL NO. 40840      000032      CLIENT SAMPLE IDENTIFICATION home ec R: sink-HE      Sample Date/Time 05/22/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:40 BJ

MARTEL NO. 40840      000033      CLIENT SAMPLE IDENTIFICATION home ec L: sink-HE      Sample Date/Time 05/22/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:42 BJ

MARTEL NO. 40840      000034      CLIENT SAMPLE IDENTIFICATION home ec R: sink-HE      Sample Date/Time 05/22/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:45 BJ

MARTEL NO. 40840      000035      CLIENT SAMPLE IDENTIFICATION child care: sink-CR      Sample Date/Time 05/22/2019 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:47 BJ

MARTEL NO. 40840      000036      CLIENT SAMPLE IDENTIFICATION life skills: sink-CR      Sample Date/Time 05/22/2019 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:50 BJ

MARTEL NO. 40840      000037      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF      Sample Date/Time 05/22/2019 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:52 BJ

MARTEL NO. 40840      000038      CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF      Sample Date/Time 05/22/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:55 BJ



## Certificate of Analysis

MARTEL NO. 40840      000039      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF      Sample Date/Time 05/22/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 01:57 BJ

MARTEL NO. 40840      000040      CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF      Sample Date/Time 05/22/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:00 BJ

MARTEL NO. 40840      000041      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF      Sample Date/Time 05/22/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:12 BJ

MARTEL NO. 40840      000042      CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF      Sample Date/Time 05/22/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:24 BJ

MARTEL NO. 40840      000043      CLIENT SAMPLE IDENTIFICATION teachers lounge: sink-TL      Sample Date/Time 05/22/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:27 BJ

MARTEL NO. 40840      000044      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF      Sample Date/Time 05/22/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:29 BJ

MARTEL NO. 40840      000045      CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF      Sample Date/Time 05/22/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:32 BJ

MARTEL NO. 40840      000046      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF      Sample Date/Time 05/22/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:34 BJ



## Certificate of Analysis

MARTEL NO. 40840      000047      CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF      Sample Date/Time 05/22/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:37 BJ

MARTEL NO. 40840      000048      CLIENT SAMPLE IDENTIFICATION teachers lounge: sink-TL      Sample Date/Time 05/22/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:39 BJ

MARTEL NO. 40840      000049      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L-DF      Sample Date/Time 05/22/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:41 BJ

MARTEL NO. 40840      000050      CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF      Sample Date/Time 05/22/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:44 BJ

MARTEL NO. 40840      000051      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF      Sample Date/Time 05/22/2019 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:54 BJ

MARTEL NO. 40840      000052      CLIENT SAMPLE IDENTIFICATION corridor: water fountain r-DF      Sample Date/Time 05/22/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 02:59 BJ

MARTEL NO. 40840      000053      CLIENT SAMPLE IDENTIFICATION teachers lounge: sink-TL      Sample Date/Time 05/22/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 03:01 BJ

MARTEL NO. 40840      000054      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF      Sample Date/Time 05/22/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 03:04 BJ



# Certificate of Analysis

MARTEL NO. 40840      000055      CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF      Sample Date/Time 05/22/2019 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 03:06 BJ

MARTEL NO. 40840      000056      CLIENT SAMPLE IDENTIFICATION corridor: water fountain L -DF      Sample Date/Time 05/22/2019 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 03:09 BJ

MARTEL NO. 40840      000057      CLIENT SAMPLE IDENTIFICATION corridor: water fountain R-DF      Sample Date/Time 05/22/2019 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 03:11 BJ

MARTEL NO. 40840      000058      CLIENT SAMPLE IDENTIFICATION concessions: water fountain L -DF      Sample Date/Time 05/22/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 03:14 BJ

MARTEL NO. 40840      000059      CLIENT SAMPLE IDENTIFICATION concessions: water fountain R-DF      Sample Date/Time 05/22/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 03:16 BJ

MARTEL NO. 40840      000060      CLIENT SAMPLE IDENTIFICATION concessions: 2 comp sink-KS      Sample Date/Time 05/22/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/02/2019 03:19 BJ

MARTEL NO. 40840      000061      CLIENT SAMPLE IDENTIFICATION concessions: ice machine-IM      Sample Date/Time 05/22/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/01/2019 22:56 BJ

MARTEL NO. 40840      000062      CLIENT SAMPLE IDENTIFICATION concessions: hose bibb-OT      Sample Date/Time 05/22/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/01/2019 22:59 BJ





MARTEL NO. 40840      000063      CLIENT SAMPLE IDENTIFICATION training room: hose bibb-OT      Sample Date/Time 05/22/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.0	ug/l	EPA .200.8	2	11/01/2019 23:09 BJ

MARTEL NO. 40840      000064      CLIENT SAMPLE IDENTIFICATION corridor: water fountain-DF      Sample Date/Time 05/22/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/01/2019 23:14 BJ

MARTEL NO. 40840      000065      CLIENT SAMPLE IDENTIFICATION corridor: water fountain r-DF      Sample Date/Time 05/22/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/01/2019 23:16 BJ

MARTEL NO. 40840      000066      CLIENT SAMPLE IDENTIFICATION concessions: facing football water fount      Sample Date/Time 05/22/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/01/2019 23:18 BJ

MARTEL NO. 40840      000067      CLIENT SAMPLE IDENTIFICATION concessions: facing football water fount      Sample Date/Time 05/22/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/01/2019 23:21 BJ

MARTEL NO. 40840      000068      CLIENT SAMPLE IDENTIFICATION concessions: hose bibb-OT      Sample Date/Time 05/22/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/01/2019 23:23 BJ



**Certificate of Analysis**

**Martel Laboratories JDS Inc.**

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

Page 10 OF 10  
11/04/2019  
stdl.frx

**Notes and references:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager

# MARTEL Chain of Custody

40840

Martel Laboratories JDS, Inc. 1025 Cromwell Bridge Road, Baltimore, Maryland 21286 410 825-7790, Fax 410 821-1054, email: martel@martellabs.com

Charles County PS Drinking Water Lead Testing 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

ALL OUTLETS WERE FLUSHED NIGHT BEFORE SAMPLING AS BELOW:

BETWEEN 5-21-19 6:00pm PM and 8:00pm 5-21-19 PM

Sampling Date: 5-22-19 Relinquished By: Alan Shirley

Received at Martel by [Signature] Date/Time: 5/22/19 12:15  
[Signature] 5/22/19 15:00

Martel Lab No: **40840** 60- St. Charles HS PSC # 08.046 5305 Piney Church Road Waldorf, MD 20602 School Dude Work Order #

Sample Floor Plan Id #	Outlet Code	Bldg Floor	Description Location	Time	Sampler Employee Code	Notes
1	DF	1st floor	cafeteria-water fountain (L)	5:00am	36552	
2	DF		cafeteria-water fountain (R)	5:01		
3	KS		kitchen-2 comp sink	5:02		
4	KS		kitchen-island sink Across from G110	5:03		
5	KS		kitchen-island sink BY oven	5:04		
6	KS		kitchen-island sink at freezer	5:05		
7	OT		kitchen-kettle	5:06		
8	IM		kitchen-ice maker	5:07		
9	KS		kitchen-3 comp sink L	5:08		
10	KS		kitchen-3 comp sink R	5:09		
11	DF		boys locker room-water fountain	5:10		
12	DF		boys locker room-water fountain	5:11		
13	OT		training room-sink	5:12		
14	IM		training room-ice machine	5:13		
15	DF		girls locker room-water fountain	5:14		
16	DF		girls locker room-water fountain	5:15		
17	DF		corridor-water fountain L	5:16		↓
18	DF		corridor-water fountain R	5:17	36552	
19	DF		corridor-water fountain L	5:00am	38697	
20	DF		corridor-water fountain R	5:01		
21	CR		concessions-sink	5:02		
22	DF		corridor-water fountain L	5:03		
23	DF		corridor-water fountain R	5:04		
24	DF		corridor-water fountain L	5:05		
25	DF		corridor-water fountain R	5:06		↓

MARTEL Chain of Custody

40840 38097

26	NO		nurse office-sink	5:07	
27	NO		nurse office-sink	5:08	
28	HE		home ec-sink	5:09	
29	HE		home ec L-sink	5:10	
30	HE		home ec R-sink	5:11	↓
31	HE		home ec L-sink	5:12	38097
32	HE		home ec R-sink	5:00	31130
33	HE		home ec L-sink	5:01	
34	HE		home ec R-sink	5:02	
35	CR		child care-sink	5:03	
36	CR		life skills-sink	5:04	
37	DF		corridor-water fountain L	5:05	
38	DF		corridor-water fountain R	5:06	
39	DF		corridor-water fountain L	5:07	
40	DF		corridor-water fountain R	5:08	
41	DF	2nd floor	corridor-water fountain L	5:09	
42	DF		corridor-water fountain R	5:10	
43	TL		teachers lounge-sink	5:11	
44	DF		corridor-water fountain L	5:12	
45	DF		corridor-water fountain R	5:13	
46	DF		corridor-water fountain L	5:14	
47	DF		corridor-water fountain (R)	5:15	
48	TL	3rd floor	Teacher Lounge sink	5:16	
49	DF		corridor water fountain (L)	5:17	
50	DF		corridor water fountain (R)	5:18	↓
51	DF		corridor-water fountain (L)	5:19	31130
52	DF		corridor water fountain (R)	5:00	34264
53	TL	4th floor	Teachers Lounge sink	5:01	
54	DF		corridor water fountain (L)	5:02	
55	DF		corridor water fountain (R)	5:03	
56	DF		corridor water fountain (L)	5:04	
57	DF		corridor water fountain (R)	5:05	
58	DF	concessions sink	concessions-water fountain (L)	5:06	
59	DF		concession-water fountain (R)	5:07	
60	KS		concessions - 2 comp sink	5:08	↓

MARTEL Chain of Custody

40840

61	IM	concession stand	concessions: Ice maker	5:09	34264	
62	OT	↓	Concession - hose bib.	5:10	↓	
63	OT	1st Floor	Training Rm (Hose bib)	5:12		
64	DF	1st Floor	Corridor water fountain (L)	5:14		
65	DF	1st Floor	Corridor water fountain (R)	5:15		
66	DF	concession stand	concession stand facing football field water fountain on (L)	5:16		
67	DF	↓	concession stand facing football field water fountain on (R)	5:17		
68	OT	↓	concession stand Hose bib	5:18	↓	