



Charles County Public Schools
 P.O. Box 2770
 5980 Radio Station Road
 La Plate, MD 20646

Monday, February 10, 2020

Certificate of Analysis
FINAL

Attention:

*Report for Lab No: 48238.
 Retest samples picked up by Martel on 12/18/2019.
 Project Identification: MD HB 270
 School: 38 Stoddert Middle School PSC 08.002*

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48238 000005	BSMS-5-OT: Kitchen-Kettle on left	12/06/2019 06:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	89.1 ug/l* EPA .200.8 2	02/07/2020 12:52 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48238 000006	BSMS-6-OT: Kitchen-Kettle on right	12/06/2019 06:25
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	95.4 ug/l* EPA .200.8 2	02/07/2020 12:55 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48238 000014	BSMS-14-HE: Food Lab-sink	12/06/2019 06:30
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	5.55 ug/l EPA .200.8 2	02/07/2020 12:57 BJ

MARTEL



Certificate of Analysis

Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

Page 2 OF 2
02/10/2020
stdl.frx

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager