



**Charles County Public Schools**

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

Monday, September 16, 2019

***Certificate of Analysis***  
**FINAL**

**Attention:**

*Report for Lab No: 40813.  
Samples picked up by Martel on April 10, 2019.  
Project Identification: MD HB 270  
School: 15 Eva Turner Elementary School.*

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40813	000001	ETES-1-OT: kitchen-kettle	04/09/2019 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	11.5	ug/l	EPA .200.8	2	09/13/2019 17:43 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40813	000002	ETES-2-KS: kitchen 3 comp sink-sink on left	04/09/2019 05:01			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	8.58	ug/l	EPA .200.8	2	09/13/2019 17:55 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40813	000003	ETES-3-KS: kitchen 3 comp sink-sink on right	04/09/2019 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.70	ug/l	EPA .200.8	2	09/13/2019 17:57 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40813	000004	ETES-4-KS: Kitchen -sink island	04/09/2019 05:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.02	ug/l	EPA .200.8	2	09/13/2019 17:59 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40813	000005	ETES-5-KS: Kitchen-sink island	04/09/2019 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	6.91	ug/l	EPA .200.8	2	09/13/2019 18:02 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40813	000006	ETES-6-IM: kitchen-ice maker	04/09/2019 05:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 18:04 BJ	



MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-7-DF: corridor-water fountain      Sample Date/Time 04/09/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.3	ug/l	EPA .200.8	2	09/13/2019 18:07 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-8-CF: special education-sink      Sample Date/Time 04/09/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	177	ug/l*	EPA .200.8	2	09/13/2019 18:09 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-9-DF: special education-bubbler      Sample Date/Time 04/09/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	99.7	ug/l*	EPA .200.8	2	09/13/2019 18:11 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-10-CF: Art Room-sink on left      Sample Date/Time 04/09/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	30.1	ug/l*	EPA .200.8	2	09/13/2019 18:14 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-11-DF: Art Room-bubbler on left      Sample Date/Time 04/09/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.4	ug/l	EPA .200.8	2	09/13/2019 18:24 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-12-CF: Art Room-Sink on right      Sample Date/Time 04/09/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	62.9	ug/l*	EPA .200.8	2	09/13/2019 18:29 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-13-DF: Art Room-bubbler on right      Sample Date/Time 04/09/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.6	ug/l	EPA .200.8	2	09/13/2019 18:31 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-14-CF: reading recovery room-sink      Sample Date/Time 04/09/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.9	ug/l*	EPA .200.8	2	09/13/2019 18:34 BJ



MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-15-DF: reading recovery room-bubbler      Sample Date/Time 04/09/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	20.8	ug/l*	EPA .200.8	2	09/13/2019 18:36 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-16-NO: health room-sink      Sample Date/Time 04/09/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	17.9	ug/l	EPA .200.8	2	09/13/2019 18:38 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-17-TL: teacher lounge-sink      Sample Date/Time 04/09/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.34	ug/l	EPA .200.8	2	09/13/2019 18:41 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-18-DF: corridor-water fountain      Sample Date/Time 04/09/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 18:43 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-19-CR: library office-sink coffee pot      Sample Date/Time 04/09/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.70	ug/l	EPA .200.8	2	09/13/2019 18:46 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-20-DF: corridor-water fountain      Sample Date/Time 04/09/2019 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 18:48 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-21-CF: corridor-sink on left      Sample Date/Time 04/09/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.1	ug/l	EPA .200.8	2	09/13/2019 19:00 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-22-DF: corridor-bubbler      Sample Date/Time 04/09/2019 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.99	ug/l	EPA .200.8	2	09/13/2019 19:12 BJ



MARTEL NO. 40813      000023      CLIENT SAMPLE IDENTIFICATION ETES-23-CF: corridor-sink      Sample Date/Time 04/09/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.8	ug/l	EPA .200.8	2	09/13/2019 19:15 BJ

MARTEL NO. 40813      000024      CLIENT SAMPLE IDENTIFICATION ETES-24-DF: corridor-bubbler      Sample Date/Time 04/09/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.0	ug/l	EPA .200.8	2	09/13/2019 19:17 BJ

MARTEL NO. 40813      000025      CLIENT SAMPLE IDENTIFICATION ETES-25-CF: corridor-sink on left      Sample Date/Time 04/09/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.6	ug/l	EPA .200.8	2	09/13/2019 19:20 BJ

MARTEL NO. 40813      000026      CLIENT SAMPLE IDENTIFICATION ETES-26-DF: corridor-bubbler      Sample Date/Time 04/09/2019 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.63	ug/l	EPA .200.8	2	09/13/2019 19:22 BJ

MARTEL NO. 40813      000027      CLIENT SAMPLE IDENTIFICATION ETES-27-CF: corridor-sink on right      Sample Date/Time 04/09/2019 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.95	ug/l	EPA .200.8	2	09/13/2019 19:24 BJ

MARTEL NO. 40813      000028      CLIENT SAMPLE IDENTIFICATION ETES-28-DF: corridor-bubbler      Sample Date/Time 04/09/2019 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.11	ug/l	EPA .200.8	2	09/13/2019 19:27 BJ

MARTEL NO. 40813      000029      CLIENT SAMPLE IDENTIFICATION ETES-29-CF: Classroom 209-sink      Sample Date/Time 04/09/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	23.4	ug/l*	EPA .200.8	2	09/13/2019 19:29 BJ

MARTEL NO. 40813      000030      CLIENT SAMPLE IDENTIFICATION ETES-30-DF: Classroom 209-bubbler      Sample Date/Time 04/09/2019 05:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	35.8	ug/l*	EPA .200.8	2	09/13/2019 19:32 BJ



MARTEL NO. 40813      000031      CLIENT SAMPLE IDENTIFICATION ETES-31-CF: Classroom 209-sink      Sample Date/Time 04/09/2019 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.3	ug/l*	EPA .200.8	2	09/13/2019 19:41 BJ

MARTEL NO. 40813      000032      CLIENT SAMPLE IDENTIFICATION ETES-32-DF: Classroom 209-bubbler      Sample Date/Time 04/09/2019 05:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	22.6	ug/l*	EPA .200.8	2	09/13/2019 19:46 BJ

MARTEL NO. 40813      000033      CLIENT SAMPLE IDENTIFICATION ETES-33-CF: Classroom 210-sink on left      Sample Date/Time 04/09/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	29.7	ug/l*	EPA .200.8	2	09/13/2019 19:48 BJ

MARTEL NO. 40813      000034      CLIENT SAMPLE IDENTIFICATION ETES-34-DF: Classroom 210-bubbler      Sample Date/Time 04/09/2019 05:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.5	ug/l*	EPA .200.8	2	09/13/2019 19:51 BJ

MARTEL NO. 40813      000035      CLIENT SAMPLE IDENTIFICATION ETES-35-CF: Classroom 210-sink on right      Sample Date/Time 04/09/2019 05:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	23.6	ug/l*	EPA .200.8	2	09/13/2019 19:53 BJ

MARTEL NO. 40813      000036      CLIENT SAMPLE IDENTIFICATION ETES-36-DF: Classroom 210-bubbler      Sample Date/Time 04/09/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.79	ug/l	EPA .200.8	2	09/13/2019 19:56 BJ

MARTEL NO. 40813      000037      CLIENT SAMPLE IDENTIFICATION ETES-37-CF: Classroom Pre-K-sink      Sample Date/Time 04/09/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 19:58 BJ

MARTEL NO. 40813      000038      CLIENT SAMPLE IDENTIFICATION ETES-38-DF: Classroom Pre-K-bubbler      Sample Date/Time 04/09/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 20:01 BJ



MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-39-CR: Classroom Pre-K-sink      Sample Date/Time 04/09/2019 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.85	ug/l	EPA .200.8	2	09/13/2019 20:03 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-40-CF: Classroom 104-sink      Sample Date/Time 04/09/2019 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.73	ug/l	EPA .200.8	2	09/13/2019 20:06 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-41-DF: Classroom 104-bubbler      Sample Date/Time 04/09/2019 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 20:18 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-42-CR: common area-sink      Sample Date/Time 04/09/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 20:30 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-43-CF: Classroom 105-sink      Sample Date/Time 04/09/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.55	ug/l	EPA .200.8	2	09/13/2019 20:32 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-44-DF: Classroom 105-bubbler      Sample Date/Time 04/09/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 20:35 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-45-CF: Classroom 106-sink      Sample Date/Time 04/09/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.42	ug/l	EPA .200.8	2	09/13/2019 20:37 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-46-DF: Classroom 106-bubbler      Sample Date/Time 04/09/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 20:40 BJ



MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-47-CF: Classroom 107-sink      Sample Date/Time 04/09/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.74	ug/l	EPA .200.8	2	09/13/2019 20:42 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-48-DF: Classroom 107-bubbler      Sample Date/Time 04/09/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 20:45 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-49-CF: Classroom 218-sink on left      Sample Date/Time 04/09/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.4	ug/l	EPA .200.8	2	09/13/2019 20:47 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-50-DF: Classroom 218-bubbler      Sample Date/Time 04/09/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.02	ug/l	EPA .200.8	2	09/13/2019 20:49 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-51-CF: Classroom 218-sink on right      Sample Date/Time 04/09/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.9	ug/l	EPA .200.8	2	09/13/2019 21:00 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-52-DF: Classroom 218-bubbler      Sample Date/Time 04/09/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	169	ug/l*	EPA .200.8	2	09/13/2019 21:04 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-53-CF: science room-sink on left      Sample Date/Time 04/09/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.3	ug/l	EPA .200.8	2	09/13/2019 21:07 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-54-DF: science room-bubbler      Sample Date/Time 04/09/2019 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.94	ug/l	EPA .200.8	2	09/13/2019 21:09 BJ



MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-55-CF: science room-sink on right      Sample Date/Time 04/09/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.9	ug/l*	EPA .200.8	2	09/13/2019 21:12 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-56-DF: science room-bubbler      Sample Date/Time 04/09/2019 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	60.3	ug/l*	EPA .200.8	2	09/13/2019 21:14 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-57-CF: corridor-sink on left      Sample Date/Time 04/09/2019 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.20	ug/l	EPA .200.8	2	09/13/2019 21:17 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-58-DF: corridor-bubbler      Sample Date/Time 04/09/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.7	ug/l	EPA .200.8	2	09/13/2019 21:19 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-59-CF: corridor-sink on right      Sample Date/Time 04/09/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.0	ug/l	EPA .200.8	2	09/13/2019 21:21 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-60-DF: corridor-bubbler      Sample Date/Time 04/09/2019 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.37	ug/l	EPA .200.8	2	09/13/2019 21:24 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-61-CF: Science Room 223-sink on left      Sample Date/Time 04/09/2019 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.30	ug/l	EPA .200.8	2	09/13/2019 21:36 BJ

MARTEL NO. 40813      CLIENT SAMPLE IDENTIFICATION ETES-62-DF: Science Room 223-bubbler      Sample Date/Time 04/09/2019 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.52	ug/l	EPA .200.8	2	09/13/2019 21:49 BJ





MARTEL NO. 40813      000063      CLIENT SAMPLE IDENTIFICATION ETES-63-CF: Science Room 223-sink on right      Sample Date/Time 04/09/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.10	ug/l	EPA .200.8	2	09/13/2019 21:51 BJ

MARTEL NO. 40813      000064      CLIENT SAMPLE IDENTIFICATION ETES-64-DF: Science Room 223-bubbler      Sample Date/Time 04/09/2019 05:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.7	ug/l	EPA .200.8	2	09/13/2019 21:53 BJ

MARTEL NO. 40813      000065      CLIENT SAMPLE IDENTIFICATION ETES-65-DF: corridor-water fountain      Sample Date/Time 04/09/2019 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 21:56 BJ

MARTEL NO. 40813      000066      CLIENT SAMPLE IDENTIFICATION ETES-66-CF: corridor-sink on left      Sample Date/Time 04/09/2019 05:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.18	ug/l	EPA .200.8	2	09/13/2019 21:58 BJ

MARTEL NO. 40813      000067      CLIENT SAMPLE IDENTIFICATION ETES-67-DF: corridor-bubbler      Sample Date/Time 04/09/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 22:01 BJ

MARTEL NO. 40813      000068      CLIENT SAMPLE IDENTIFICATION ETES-68-CF: corridor-sink on right      Sample Date/Time 04/09/2019 05:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 22:03 BJ

MARTEL NO. 40813      000069      CLIENT SAMPLE IDENTIFICATION ETES-69-DF: Science Room -bubbler      Sample Date/Time 04/09/2019 05:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 22:06 BJ

MARTEL NO. 40813      000070      CLIENT SAMPLE IDENTIFICATION ETES-70-KS: Kitchen 2 camp sink      Sample Date/Time 04/09/2019 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.63	ug/l	EPA .200.8	2	09/13/2019 22:08 BJ



MARTEL NO. 40813	000071	CLIENT SAMPLE IDENTIFICATION ETES-71-DF: corridor water fountain	Sample Date/Time 04/09/2019 05:38
---------------------	--------	---------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 22:18 BJ

MARTEL NO. 40813	000072	CLIENT SAMPLE IDENTIFICATION ETES-72-IM: common area at new addition	Sample Date/Time 04/09/2019 05:38
---------------------	--------	-------------------------------------------------------------------------	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/13/2019 22:23 BJ

Page 10 OF 10

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
 PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

### Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.  
 The results presented herein relate only to the samples or items tested.

  
 Project Manager