



**Charles County Public Schools**

P.O. Box 2770  
5980 Radio Station Road  
La Plate, MD 20646

**Attention:**

Report for Lab No: 40814.  
Samples picked up by Martel on April 10, 2019.  
Project Identification: MD HB 270  
School: 19 William B. Wade ES.

Monday, September 9, 2019

***Certificate of Analysis***  
**FINAL**

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40814 000001	WWES-1-IM: kitchen -ice maker	04/10/2019 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 09/08/2019 15:36 BJ
40814 000002	WWES-2-KS: kitchen 2 comp sink -sink	04/10/2019 05:01
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	3.79 ug/l EPA .200.8	2 09/08/2019 15:48 BJ
40814 000003	WWES-3-KS: kitchen -island sink	04/10/2019 05:02
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	3.26 ug/l EPA .200.8	2 09/08/2019 15:51 BJ
40814 000004	WWES-4-KS: kitchen-island sink	04/10/2019 05:03
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	42.4 ug/l* EPA .200.8	2 09/08/2019 15:53 BJ
40814 000005	WWES-5-KS: kitchen 3 comp sink-sink on left	04/10/2019 05:04
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	2.70 ug/l EPA .200.8	2 09/08/2019 15:56 BJ
40814 000006	WWES-6-KS: kitchen 3 comp sink-sink on right	04/10/2019 05:05
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	5.14 ug/l EPA .200.8	2 09/08/2019 15:58 BJ



MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000007      WWES-7-DF: kitchen -water fountain      04/10/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:00 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000008      WWES-8-DF: corridor-water fountain      04/10/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:03 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000009      WWES-9-DF: corridor-water fountain      04/10/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:05 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000010      WWES-10-CF: Classroom 129-sink      04/10/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.46	ug/l	EPA .200.8	2	09/08/2019 16:08 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000011      WWES-11-DF: Classroom 129-bubbler      04/10/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.67	ug/l	EPA .200.8	2	09/08/2019 16:18 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000012      WWES-12-CF: Classroom 128-sink      04/10/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.37	ug/l	EPA .200.8	2	09/08/2019 16:23 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000013      WWES-13-DF: Classroom 128-bubbler      04/10/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.95	ug/l	EPA .200.8	2	09/08/2019 16:25 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000014      WWES-14-CF: Classroom 114-sink      04/10/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:27 BJ



MARTEL NO. 40814      000015      CLIENT SAMPLE IDENTIFICATION WWES-15-DF: Classroom 114-bubbler      Sample Date/Time 04/10/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:30 BJ

MARTEL NO. 40814      000016      CLIENT SAMPLE IDENTIFICATION WWES-16-CF: Classroom 115-sink      Sample Date/Time 04/10/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.44	ug/l	EPA .200.8	2	09/08/2019 16:32 BJ

MARTEL NO. 40814      000017      CLIENT SAMPLE IDENTIFICATION WWES-17-DF: Classroom 115-bubbler      Sample Date/Time 04/10/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:35 BJ

MARTEL NO. 40814      000018      CLIENT SAMPLE IDENTIFICATION WWES-18-CF: Classroom 127-sink      Sample Date/Time 04/10/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:37 BJ

MARTEL NO. 40814      000019      CLIENT SAMPLE IDENTIFICATION WWES-19-DF: Classroom 127-bubbler      Sample Date/Time 04/10/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:40 BJ

MARTEL NO. 40814      000020      CLIENT SAMPLE IDENTIFICATION WWES-20-CF: Classroom 126-sink      Sample Date/Time 04/10/2019 05:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.74	ug/l	EPA .200.8	2	09/08/2019 16:42 BJ

MARTEL NO. 40814      000021      CLIENT SAMPLE IDENTIFICATION WWES-21-DF: Classroom 126-bubbler      Sample Date/Time 04/10/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 16:54 BJ

MARTEL NO. 40814      000022      CLIENT SAMPLE IDENTIFICATION WWES-22-CF: Classroom 117-sink      Sample Date/Time 04/10/2019 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:06 BJ



MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-23-DF: Classroom 117-bubbler      Sample Date/Time 04/10/2019 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:09 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-24-CF: Classroom 110-sink      Sample Date/Time 04/10/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:11 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-25-DF: Classroom 110-bubbler      Sample Date/Time 04/10/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:14 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-26-CF: media center activity -sink      Sample Date/Time 04/10/2019 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.47	ug/l	EPA .200.8	2	09/08/2019 17:16 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-27-CR: media center office-sink      Sample Date/Time 04/10/2019 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.24	ug/l	EPA .200.8	2	09/08/2019 17:18 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-28-CF: Classroom 125-sink      Sample Date/Time 04/10/2019 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:21 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-29-DF: Classroom 125-bubbler      Sample Date/Time 04/10/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:23 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-30-CF: Classroom 124-sink      Sample Date/Time 04/10/2019 05:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.69	ug/l	EPA .200.8	2	09/08/2019 17:26 BJ



MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-31-DF: Classroom 124-bubbler      Sample Date/Time 04/10/2019 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:35 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-32-DF: corridor-water fountain      Sample Date/Time 04/10/2019 05:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:40 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-33-CF: Classroom 118-sink      Sample Date/Time 04/10/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:43 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-34-DF: Classroom 118-bubbler      Sample Date/Time 04/10/2019 05:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:45 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-35-CF: Classroom 123-sink      Sample Date/Time 04/10/2019 05:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.84	ug/l	EPA .200.8	2	09/08/2019 17:47 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-36-DF: Classroom 123-bubbler      Sample Date/Time 04/10/2019 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:50 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-37-CF: Classroom 122-sink      Sample Date/Time 04/10/2019 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.74	ug/l	EPA .200.8	2	09/08/2019 17:52 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-38-DF: Classroom 122-bubbler      Sample Date/Time 04/10/2019 05:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:55 BJ



MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000039      WWES-39-CF: Classroom 120-sink      04/10/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 17:57 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000040      WWES-40-DF: Classroom 120-bubbler      04/10/2019 05:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:00 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000041      WWES-41-CF: Classroom 121-sink      04/10/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:12 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000042      WWES-42-DF: Classroom 121-bubbler      04/10/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:24 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000043      WWES-43-CF: Classroom 140-sink      04/10/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.66	ug/l	EPA .200.8	2	09/08/2019 18:27 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000044      WWES-44-DF: Classroom 140-bubbler      04/10/2019 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:29 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000045      WWES-45-CF: Classroom 139-sink      04/10/2019 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.49	ug/l	EPA .200.8	2	09/08/2019 18:31 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000046      WWES-46-DF: Classroom 139-bubbler      04/10/2019 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:34 BJ



MARTEL NO. 40814      000047      CLIENT SAMPLE IDENTIFICATION WWES-47-CF: Classroom 138-sink      Sample Date/Time 04/10/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.21	ug/l	EPA .200.8	2	09/08/2019 18:36 BJ

MARTEL NO. 40814      000048      CLIENT SAMPLE IDENTIFICATION WWES-48-DF: Classroom 138-bubbler      Sample Date/Time 04/10/2019 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:39 BJ

MARTEL NO. 40814      000049      CLIENT SAMPLE IDENTIFICATION WWES-49-CF: Classroom 137-sink      Sample Date/Time 04/10/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.72	ug/l	EPA .200.8	2	09/08/2019 18:41 BJ

MARTEL NO. 40814      000050      CLIENT SAMPLE IDENTIFICATION WWES-50-DF: Classroom 137-bubbler      Sample Date/Time 04/10/2019 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:44 BJ

MARTEL NO. 40814      000051      CLIENT SAMPLE IDENTIFICATION WWES-51-DF: corridor-water fountain      Sample Date/Time 04/10/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:54 BJ

MARTEL NO. 40814      000052      CLIENT SAMPLE IDENTIFICATION WWES-52-CF: Classroom 134-sink      Sample Date/Time 04/10/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 18:59 BJ

MARTEL NO. 40814      000053      CLIENT SAMPLE IDENTIFICATION WWES-53-DF: Classroom 134-bubbler      Sample Date/Time 04/10/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:01 BJ

MARTEL NO. 40814      000054      CLIENT SAMPLE IDENTIFICATION WWES-54-CF: Classroom 135-sink      Sample Date/Time 04/10/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:03 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40814 000055	WWES-55-DF: Classroom 135-bubbler	04/10/2019 05:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:06 BJ
40814 000056	WWES-56-CF: Classroom 133-sink	04/10/2019 05:15			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:08 BJ
40814 000057	WWES-57-DF: Classroom 133-bubbler	04/10/2019 05:16			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:11 BJ
40814 000058	WWES-58-CF: Classroom 132-sink	04/10/2019 05:17			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:13 BJ
40814 000059	WWES-59-DF: Classroom 132-bubbler	04/10/2019 05:18			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:16 BJ
40814 000060	WWES-60-CF: Classroom 132-sink	04/10/2019 05:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:18 BJ
40814 000061	WWES-61-DF: Classroom 132-bubbler	04/10/2019 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:31 BJ
40814 000062	WWES-62-CF: Classroom 105-sink	04/10/2019 05:21			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.85	ug/l	EPA .200.8	2	09/08/2019 19:43 BJ





MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-63-DF: Classroom 105-bubbler      Sample Date/Time 04/10/2019 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:45 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-64-CF: Classroom 104-sink      Sample Date/Time 04/10/2019 05:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.66	ug/l	EPA .200.8	2	09/08/2019 19:48 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-65-DF: Classroom 104-bubbler      Sample Date/Time 04/10/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.16	ug/l	EPA .200.8	2	09/08/2019 19:50 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-66-CF: Classroom 106-sink      Sample Date/Time 04/10/2019 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.13	ug/l	EPA .200.8	2	09/08/2019 19:52 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-67-DF: Classroom 106-bubbler      Sample Date/Time 04/10/2019 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:55 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-68-CF: Classroom 107-sink      Sample Date/Time 04/10/2019 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 19:57 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-69-DF: Classroom 107-bubbler      Sample Date/Time 04/10/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 20:00 BJ

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION WWES-70-CF: Classroom 108-sink      Sample Date/Time 04/10/2019 05:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.39	ug/l	EPA .200.8	2	09/08/2019 20:02 BJ



MARTEL NO. 40814	000071	CLIENT SAMPLE IDENTIFICATION WWES-71-DF: Classroom 108-bubbler	Sample Date/Time 04/10/2019 05:30
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.23	ug/l	EPA .200.8	2	09/08/2019 20:12 BJ

MARTEL NO. 40814	000072	CLIENT SAMPLE IDENTIFICATION WWES-72-CF: Classroom 103-sink	Sample Date/Time 04/10/2019 05:31
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 20:17 BJ

MARTEL NO. 40814	000073	CLIENT SAMPLE IDENTIFICATION WWES-73-DF: Classroom 103-bubbler	Sample Date/Time 04/10/2019 05:32
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 20:20 BJ

MARTEL NO. 40814	000074	CLIENT SAMPLE IDENTIFICATION WWES-74-CF: Classroom 102-sink on left	Sample Date/Time 04/10/2019 05:33
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.31	ug/l	EPA .200.8	2	09/08/2019 20:22 BJ

MARTEL NO. 40814	000075	CLIENT SAMPLE IDENTIFICATION WWES-75-IM: Teacher Lounge Ice Maker	Sample Date/Time 04/10/2019 05:34
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 20:25 BJ

MARTEL NO. 40814	000076	CLIENT SAMPLE IDENTIFICATION WWES-76-CF: Classroom 102-sink on right	Sample Date/Time 04/10/2019 05:35
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.18	ug/l	EPA .200.8	2	09/08/2019 20:27 BJ

MARTEL NO. 40814	000077	CLIENT SAMPLE IDENTIFICATION WWES-77-DF: Classroom 102-bubbler right	Sample Date/Time 04/10/2019 05:36
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 20:29 BJ

MARTEL NO. 40814	000078	CLIENT SAMPLE IDENTIFICATION WWES-78-CF: Classroom 109-sink	Sample Date/Time 04/10/2019 05:37
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.13	ug/l	EPA .200.8	2	09/08/2019 20:32 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40814 000079	WWES-79-DF: Classroom 109-bubbler	04/10/2019 05:38			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 20:34 BJ
40814 000080	WWES-80-DF: corridor-water fountain	04/10/2019 05:39			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/08/2019 20:37 BJ
40814 000081	WWES-81-CF: Classroom 101-sink on left	04/10/2019 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.72	ug/l	EPA .200.8	2	09/03/2019 18:50 CSG
40814 000082	WWES-82-DF: Classroom 101-bubbler	04/10/2019 05:41			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/03/2019 19:02 CSG
40814 000083	WWES-83-CR: Classroom 101-sink on right	04/10/2019 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/03/2019 19:04 CSG
40814 000084	WWES-84-CF: Classroom 100-sink on left	04/10/2019 05:43			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.42	ug/l	EPA .200.8	2	09/03/2019 19:07 CSG
40814 000085	WWES-85-DF: Classroom 100-bubbler	04/10/2019 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/03/2019 19:09 CSG
40814 000086	WWES-86-CR: Classroom 100-sink on right	04/10/2019 05:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/03/2019 19:11 CSG



MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000087      WWES-87-TL: teacher lounge-sink      04/10/2019 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/03/2019 19:14 CSG

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000088      WWES- 88-CF: music room      04/10/2019 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.03	ug/l	EPA .200.8	2	09/03/2019 19:16 CSG

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000089      WWES-89-DF: music room      04/10/2019 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/03/2019 19:19 CSG

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000090      WWES-90-CR: special ed      04/10/2019 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.73	ug/l	EPA .200.8	2	09/03/2019 19:21 CSG

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000091      WWES-91-CR: CR119 special education      04/10/2019 05:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.5	ug/l	EPA .200.8	2	09/03/2019 19:31 CSG

MARTEL NO. 40814      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
000092      WWES-92-IM: cr 132 Ice Maker      04/10/2019 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/03/2019 19:36 CSG



**Martel Laboratories JDS Inc.**

Page 13 OF 13

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

CHARPS

09/09/2019


stddl.frx

**Notes and references:**

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

\* Indicates result(s) greater than 20.5 ug/l - regulatory limit for these samples.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager